

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with *British Standard 7671 – Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZK

CRN/ N/A Contractor's Reference Number

## DETAILS OF THE CLIENT

Client and address  
 Mr.D.Michael  
 Bath Street  
 Stroud  
 Gloucestershire  
 Postcode GL5 3BZ

## ADDRESS OF THE INSTALLATION

Installation address  
 Flat 1,Bath Street  
 Stroud  
 Gloucestershire  
 Postcode GL5 3BZ

## DETAILS OF THE INSTALLATION


Extent of the installation work covered by this certificate  
 Fixed wiring only, Flat 1

The installation is  
 New   
 An addition   
 An alteration


## DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I, being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my signature adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671, 17th Edition amended to 2015 (date) except for the departures, if any, detailed as follows:  
 Details of departures from BS 7671, as amended (Regulations 120.3, 133.5)  
 None

The extent of liability of the signatory is limited to the work described above as the subject of this certificate. For the **DESIGN**, the **CONSTRUCTION** and the **INSPECTION AND TESTING** of the installation

Signature  Name (CAPITALS) KEVIN KEATES Date 20/07/2015

**The results of the inspection and testing reviewed by the Qualified Supervisor**

Signature  Name (CAPITALS) KEVIN KEATES Date 20/07/2015

## PARTICULARS OF THE APPROVED CONTRACTOR

Trading title  
 K M Keates Electrical Contracting L

Address  
 Manor Farm House  
 Gloucester

Telephone No 07831 695185 Postcode GL2 5JU

NICEIC Enrolment No (Essential information) 0 1 2 2 0 9 Branch No (if applicable) 0 0 0

## NEXT INSPECTION

§ Enter interval in terms of years, months or weeks, as appropriate

I RECOMMEND that this installation is further inspected and tested after an interval of not more than 10 years

## COMMENTS ON EXISTING INSTALLATION

Note: Enter 'NONE' or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation

None

In the case of an alteration or additions see Section 633 of BS 7671

## SCHEDULE OF ADDITIONAL RECORDS\*

See attached schedule

\* Where the electrical work to which this certificate relates includes the installation of a fire detection/ alarm system (or a part of such a system), this electrical safety certificate should be accompanied by the particular certificate for the system.

This certificate is based on the model forms shown in Appendix 6 of BS 7671.

Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

## NOTES FOR RECIPIENT

**THIS SAFETY CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE**

**IF YOU WERE THE PERSON ORDERING THE WORK, BUT NOT THE OWNER OR USER OF THE INSTALLATION, YOU SHOULD PASS THIS CERTIFICATE, OR A FULL COPY OF IT INCLUDING THESE NOTES, IMMEDIATELY TO THE OWNER OR USER OF THE INSTALLATION.**

**This safety certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected, tested and verified in accordance with the national standard for the safety of electrical installations, British Standard 7671 (as amended) - *Requirements for Electrical Installations* (the IET Wiring Regulations).**

**Where, as will often be the case, the installation incorporates a residual current device (RCD), there should be a notice at or near the consumer unit stating that the device should be tested at quarterly intervals. For safety reasons, it is important that you carry out the test regularly.**

**Also for safety reasons, the complete electrical installation will need to be inspected and tested at appropriate intervals by a skilled person or persons competent in such work. NICEIC\* recommends that you engage the services of an Approved Contractor for this purpose. The maximum interval recommended before the next inspection is stated on Page 1 under *Next Inspection*. There should also be a notice at or near the consumer unit indicating when the inspection of the installation is next due.**

Only an NICEIC Approved Contractor or Conforming Body responsible for the construction of the electrical installation is authorised to issue this NICEIC certificate.

The Domestic Electrical Installation Certificate consists of at least four pages. The certificate is invalid if pages (containing schedules) are missing. The certificate has a printed seven-digit serial number which is traceable to the Approved Contractor to which it was supplied.

This certificate is intended to be issued for either the initial certification of a new electrical installation, or for new work associated with an alteration or addition to an existing electrical installation, in a single dwelling (house or individual flat). For new electrical installation work in other than a single dwelling, a full Electrical Installation Certificate should have been issued.

This certificate should not have been issued for reporting on the condition of an existing electrical installation. An Electrical Installation Condition Report or, where appropriate, a Domestic Electrical Installation Condition Report should be issued for such an inspection.

You should have received the certificate marked 'Original' and the Approved Contractor should have retained the certificate marked 'Duplicate'.

**The 'Original' certificate should be kept in a safe place and shown to any person inspecting or undertaking work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new owner or user that the electrical installation work complied with the requirements of the national electrical safety standard at the time the certificate was issued.**

Page 1 of this certificate provides details of the electrical installation, together with the names and signatures of the persons certifying the installation work and reviewing the results of inspection and testing on behalf of the Approved Contractor responsible for the work, details of which are also given on that page.

Certification provides an assurance that the electrical installation work has been fully inspected and tested, and that the work has been carried out in accordance with the requirements of BS 7671 (except for any departures recorded in the appropriate part of the certificate).

All unshaded boxes should have been completed either by insertion of the relevant details or by entering 'N/A', meaning 'Not Applicable', where appropriate.

Where the electrical work to which this certificate relates includes the provision of a mains powered fire detection and alarm system (such as one or more smoke alarms), this electrical safety certificate must be accompanied by a separate certificate for that system in accordance with British Standard BS 5839-6: 2013: *Fire detection and fire alarm systems for buildings - Part 6: Code of practice for the design, installation, commissioning and maintenance of fire detection and fire alarm systems in domestic premises*.

Should the person ordering the work (e.g. the client, as identified on Page 1 of this certificate) have reason to believe that any element of the electrical work for which the Approved Contractor has accepted responsibility (as indicated by the signatures on this certificate) does not comply with the requirements of the national electrical safety standard (BS 7671), the person should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application and from the website. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

*\* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, the Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).*

For further information about electrical safety and how NICEIC can help you,  
**visit [www.niceic.com](http://www.niceic.com)**

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Original (To the person ordering the work)

SUPPLY CHARACTERISTICS				Nature of supply parameters				Characteristics of primary supply overcurrent protective device(s)							
System type(s)				Number and type of live conductors				Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one supply, record the higher or highest values							
TN-S	N/A	1-phase (2-wire)	✓	1-phase (3-wire)	N/A	Number of sources	1	Nominal voltage(s)	400 V	Nominal frequency, $f^{(1)}$	50 Hz	BS(EN)	88-2	Short-circuit capacity	16 kA
TN-C-S	✓	3-phase (3-wire)	N/A	3-phase (4-wire)	N/A			$U_o^{(1)}$	230 V	External earth fault loop impedance, $Z_e^{(1)}$	0.35 $\Omega$	Type	G	Confirmation of supply polarity	✓ ✓
TT	N/A	Other	Please state			Single-phase Prospective fault current, $I_{pf}^{(2/3)}$	16 kA	3-phase Prospective fault current, $I_{pf}^{(2/3)}$	N/A kA			Rated current	100 A		

PARTICULARS OF INSTALLATION AT THE ORIGIN				Main Switch/Switch-Fuse/Circuit-Breaker/RCD									
Means of earthing				Details of installation earth electrode (where applicable)				Measured $Z_e$					
Distributor's facility	✓	Type (eg rod(s), tape etc)	N/A	Location		Protective measure(s) for fault protection	ADS	Maximum demand (Load)		Type BS(EN)	BS EN 60947-3 Isolator	Voltage rating	230 V
Installation earth electrode	N/A	Electrode resistance, $R_A$	N/A $\Omega$	Method of measurement		Number of smoke alarms	2	Number of poles	2	No of poles	2	Rated current, $I_n$	80 A
Earthing conductor				Main protective bonding conductors and bonding of extraneous-conductive-parts (✓)				Supply conductors material					
Conductor material	copper	Continuity/connection verified	✓	Conductor material	copper	Conductor csa	10 mm <sup>2</sup>	Water installation pipes	✓	Structural steel	N/A	RCD operating current, $I_{\Delta n}^*$	N/A mA
Conductor csa	16 mm <sup>2</sup>	Continuity/connection verified	✓	Location (where not obvious)		Oil installation pipes	N/A	Gas installation pipes	✓	Supply conductors csa	25 mm <sup>2</sup>	RCD operating time (at $I_{\Delta n}^*$ )	N/A ms
								Rated time delay* <sup>†</sup>				N/A ms	

\* applicable only where an RCD is used as a main circuit-breaker

SCHEDULE OF ITEMS INSPECTED		† See note below
<b>1.0 CONDITION/ADEQUACY OF DISTRIBUTOR'S/SUPPLY INTAKE EQUIPMENT (the Distributor should be notified of any unsatisfactory equipment)</b>		
1.1	Service cable	✓
1.2	Service head	✓
1.3	Distributor's earthing arrangement	✓
1.4	Meter tails - Distributor/Consumer	✓
1.5	Metering equipment	✓
1.6	Means of main isolation (where present)	✓
<b>2.0 PARALLEL OR SWITCHED ALTERNATIVE SOURCES OF SUPPLY</b>		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A
2.3	Presence of alternative/additional supply warning notice(s)	✓
<b>3.0 AUTOMATIC DISCONNECTION OF SUPPLY</b>		
3.1	Presence and adequacy of protective earthing/ bonding arrangements as follows:	
a)	Distributor's earthing arrangement or installation earth electrode arrangement	N/A
b)	Earthing conductor and connections	✓
c)	Main protective bonding conductors and connections	✓
d)	Earthing/bonding labels at all appropriate locations	✓
3.2	Accessibility of:	
a)	Earthing conductor connections	✓
b)	All protective bonding connections	✓
<b>4.0 BASIC PROTECTION</b>		
4.1	Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:	
a)	Insulation of live parts e.g. conductors completely covered with durable insulating materials	✓
b)	Barriers or enclosures e.g. correct IP rating	✓
<b>5.0 ADDITIONAL PROTECTION</b>		
5.1	Presence and effectiveness of additional protection methods	
a)	RCD(s) not exceeding 30 mA operating current	✓
b)	Supplementary bonding	✓
<b>6.0 OTHER METHODS OF PROTECTION</b>		
6.1	Basic and fault protection	LOCATION
a)	SELV	N/A
b)	PELV	✓
c)	Double insulation/Reinforced insulation	✓
d)	Electrical separation for one item of equipment	✓

† All boxes must be completed. ✓ indicates that an inspection was carried out and that the result was satisfactory. 'N/A' indicates that an inspection was not applicable to the particular installation.

‡ Where a smoke alarm has been installed, separate certification is required on the appropriate form.

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Original (To the person ordering the work)

SCHEDULE OF ITEMS INSPECTED <sup>† See note below</sup>	
<b>7.0 CONSUMER UNIT(S)</b>	
7.1 Adequacy of working space/accessibility	✓
7.2 Security of fixing	✓
7.3 Adequacy / security of barriers	✓
7.4 Insulation of live parts not damaged during erection	✓
7.5 Enclosures not damaged during installation	✓
7.6 Suitability of enclosures for IP and fire ratings	✓
7.7 Presence and operation of main switch(es), linked, where appropriate	✓
7.8 Operation of circuit-breakers and RCDs to prove functionality	✓
7.9 Correct identification of circuit protective devices	✓
7.10 RCD(s) provided for fault protection, where specified	✓
7.11 RCD(s) provided for additional protection, where specified	✓
7.12 Confirmation overvoltage protection (SPDs) provided and functional where specified	✓
7.13 Presence of RCD quarterly test notice at or near the origin	✓
7.14 Presence of diagrams, charts or schedules at or near each Consumer unit(s)	✓
7.15 Presence of non-standard (mixed) cable colour warning notice at or near the appropriate distribution board, where required	✓
7.16 Presence of next inspection recommendation label	✓
7.17 Presence of other required labelling	✓
7.18 Selection of protective device(s) and base(s); correct type and rating	✓
7.19 Single-pole protective devices in line conductor only	✓
7.20 Protection against mechanical damage where cables enter equipment	✓
7.21 Protection against electromagnetic effects where cables enter ferromagnetic enclosures	✓
7.22 Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓
<b>8.0 CIRCUITS</b>	
8.1 Identification of conductors	✓
8.2 Cables adequately supported throughout their length	✓
8.3 Examination of cables for signs of mechanical damage during installation	✓
8.4 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓
8.5 Adequacy of protective devices: type and rated current for fault protection	✓
8.6 Presence and adequacy of circuit protective conductors	✓
8.7 Coordination between conductors and overload protective devices	✓
8.8 Non-sheathed cables enclosed throughout (e.g. in conduit/trunking)	✓
8.9 Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage	✓
a) Installed in prescribed zones	✓
b) Incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like	✓
8.10 Provision of additional protection by RCDs having rated residual operating current ( $I_{\Delta n}$ ) not exceeding 30 mA	
a) For mobile equipment with a current rating not exceeding 32 A for use outdoors	N/A
b) For all socket-outlets of rating 20 A or less, unless exempt	✓
c) For cables installed in walls/partitions at a depth of less than 50 mm	✓
d) For cables installed in walls/partitions containing metal parts regardless of depth	✓
8.11 Provision of fire barriers, sealing arrangements so as to minimize the spread of fire	✓
8.12 Band II cables segregated/separated from Band I cables	✓
8.13 Cables segregated/separated from non-electrical services	✓
8.14 Termination of cables at enclosures	
a) Connections under no undue strain	✓
b) No basic insulation of a conductor visible outside enclosure	✓
8.15 Circuit accessories not damaged during erection	✓
8.16 Single-pole devices for switching or protection in the line conductors only	✓
8.17 Adequacy of connections, including cpcs, within accessories and at fixed and stationary equipment	✓
8.18 Presence of appropriate devices for isolation and switching correctly located	
a) Accessible means of switching off for mechanical maintenance	✓
b) Correct operation verified (functional check)	✓
<b>9.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)</b>	
9.1 Adequacy of working space/accessibility	✓
9.2 Suitability of equipment in terms of IP and fire ratings	✓
9.3 Enclosure not damaged/deteriorated during installation so as to impair safety	✓
9.4 Cable entry holes in ceilings above luminaires, sized or sealed so as to restrict the spread of fire	✓
9.5 Recessed luminaires (downlighters)	
a) Correct type of lamps fitted	✓
b) Installed to minimise build-up of heat	✓
<b>10.0 LOCATION(S) CONTAINING A BATH OR SHOWER</b>	
10.1 Additional protection by RCD not exceeding 30 mA	
a) For low voltage circuits serving the location	✓
b) For low voltage circuits passing through Zone 1 and Zone 2 not serving the location	✓
10.2 Where used as a protective measure, requirements for SELV or PELV are met	✓
10.3 Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	✓
10.4 Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓
10.5 Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	✓
10.6 Suitability of equipment for external influences for installed location in terms of IP rating	✓
10.7 Suitability of electrical equipment for installation in a particular zone	✓
<b>11.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS</b>	
11.1 List all other special installations or locations present, if any. (Record separately the results of particular inspections applied separately)	

**SCHEDULE OF ITEMS INSPECTED BY:**

Signature  Name (Capitals): KEVIN KEATES Date: 20/07/2015

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

## CIRCUIT DETAILS TEST RESULTS

Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa		Max. disconnection time (s) by BS 7671	Overcurrent protective devices				RCD Operating current, I <sub>Δn</sub> (mA)	Maximum Z <sub>s</sub> permitted by BS 7671 (Ω)	Circuit impedances (Ω)					Insulation resistance				Polarity (✓)	Maximum measured earth fault loop impedance, Z <sub>s</sub> (Ω)	RCD										
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)			operating times		Test button operation (✓)								
														r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )	R <sub>2</sub>							at I <sub>Δn</sub> (ms)	at 5 I <sub>Δn</sub> (if applicable) (ms)									
					*																														
1	Distribution Board	A	C	1	16	16	5	1361	1	63	16	N/A	N/A	N/A	N/A	N/A	0.23	N/A	20	20	20	✓	0.34	N/A	N/A	N/A									

Location of consumer unit: **Main incomer-Basement** Designation of consumer unit: **Isolating Switch** Prospective fault current at consumer unit: **0.647** kA

TEST INSTRUMENTS		Test instruments (serial numbers) used	
Multi-function		Insulation resistance	6007773
		Continuity	6007773
		Earth electrode resistance	
		Earth fault loop impedance	6006899
		RCD	6006899

CODES FOR TYPE OF WIRING				
A	B	C	D	E
Thermoplastic insulated/sheathed cables	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in non-metallic trunking	Thermoplastic cables in non-metallic trunking
			F	G
			Thermoplastic SWA cables	Thermoplastic SWA cables
				H
				Mixed metal cables
				I
				Other (please state)

Original (To the person ordering the work)

Contractor's Reference Number

CRN/N/A

This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report

DCNC/DPNC  
 Delete as appropriate

00482726

# SCHEDULES - CONTINUATION

CIRCUIT DETAILS														TEST RESULTS															
Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD		Circuit impedances (Ω)				Insulation resistance				Polarity	Maximum measured earth fault loop impedance, Z <sub>s</sub> (Ω)	RCD					
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I <sub>n</sub> (mA)	Maximum Z <sub>s</sub> permitted by BS 7671 (Ω)	Ring final circuits only (measured end to end)		All circuits (At least one column to be completed)		Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)			operating times		Test button operation			
														r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )							R <sub>2</sub>	at I <sub>Δn</sub> (ms)		at 5 I <sub>Δn</sub> (if applicable) (ms)		
																											✓	Ω	(ms)
*	Distribution Board	A	C	1	16	16	5	1361	1	63	16	N/A	N/A	N/A	N/A	N/A	0.23	N/A	20	20	20	✓	0.34	N/A	N/A	N/A			
1	Hob	A	102	1	6	2.5	0.4	60898	B	40	6	30	1.09	N/A	N/A	N/A	0.23	N/A	20	20	20	✓	0.58	29	20	✓			
2	Sockets General	A	102	14	2.5	1.5	0.4	60898	B	32	6	30	1.36	0.51	0.51	0.91	0.35	N/A	N/A	20	20	20	✓	0.59	29	20	✓		
3	Lights general	A	102	21	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	0.98	N/A	20	20	20	✓	0.76	29	20	✓			
4	SPARE																												
5	SPARE																												
6	Oven	A	102	1	2.5	1.5	0.4	60898	B	16	6	30	2.73	N/A	N/A	N/A	0.21	N/A	20	20	20	✓	0.56	29	20	✓			
7	socket	A	102	1	2.5	1.5	0.4	60898	B	16	6	30	2.73	N/A	N/A	N/A	0.13	N/A	20	20	20	✓	0.56	28	20	✓			
8	Lights general	A	100	6	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	0.65	N/A	20	20	20	✓	1.22	28	20	✓			
9	Smoke detectors	A	100	2	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	0.89	N/A	20	20	20	✓	1.02	28	20	✓			
Location of consumer unit		Kitchen			Designation of consumer unit			Distribution Board			Prospective fault current at consumer unit			0.647			kA												
TEST INSTRUMENTS														Test instruments (serial numbers) used															
Multi-function		Insulation resistance	6007773	Continuity	6007773	Earth electrode resistance		Earth fault loop impedance	6006899	RCD	6006899																		

																														0 (Other - please state)
																														Mineral-insulated cables
																														Thermosetting SWA cables
																														Thermoplastic/SWA cables
																														Thermoplastic cables in metal trunking
																														Thermoplastic cables in non-metallic trunking
																														Thermoplastic cables in non-metallic conduit
																														Thermoplastic cables in metallic conduit

Original (To the person ordering the work)



APPROVED CONTRACTOR

This safety certificate is an important and valuable document which should be retained for future reference

This certificate is not valid if the serial number has been defaced or altered

DCN7C/

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with *British Standard 7671 – Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZK

CRN/N/A

Contractor's Reference Number

## DETAILS OF THE CLIENT

Client and address  
Mr.D.Michael  
Bath Street  
Stroud  
Gloucestershire

Postcode GL5 3BZ

## ADDRESS OF THE INSTALLATION

Installation address  
Flat 2,Bath Street  
Stroud  
Gloucestershire

Postcode GL5 3BZ

## DETAILS OF THE INSTALLATION

Extent of the installation work covered by this certificate  
Fixed wiring only, Flat 2

The installation is  
New   
An addition --  
An alteration --

## DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I, being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my signature adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671, 17th Edition amended to 2015 (date) except for the departures, if any, detailed as follows:

Details of departures from BS 7671, as amended (Regulations 120.3, 133.5)

None

The extent of liability of the signatory is limited to the work described above as the subject of this certificate. For the **DESIGN**, the **CONSTRUCTION** and the **INSPECTION AND TESTING** of the installation

Signature \_\_\_\_\_ Name (CAPITALS) \_\_\_\_\_ Date \_\_\_\_\_

The results of the inspection and testing reviewed by the Qualified Supervisor

Signature \_\_\_\_\_ Name (CAPITALS) \_\_\_\_\_ Date \_\_\_\_\_

## PARTICULARS OF THE APPROVED CONTRACTOR

Trading title  
K M Keates Electrical Contracting L

Address  
Manor Farm House  
Gloucester



Telephone No 07831 695185

Postcode GL2 5JU

NICEIC Enrolment No (Essential information) 0 1 2 2 0 9

Branch No (if applicable) 0 0 0

## NEXT INSPECTION

§ Enter interval in terms of years, months or weeks, as appropriate

I RECOMMEND that this installation is further inspected and tested after an interval of not more than 10 years

## COMMENTS ON EXISTING INSTALLATION

Note: Enter 'NONE' or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation

None

In the case of an alteration or additions see Section 633 of BS 7671

## SCHEDULE OF ADDITIONAL RECORDS\*

See attached schedule

\* Where the electrical work to which this certificate relates includes the installation of a fire detection/alarm system (or a part of such a system), this electrical safety certificate should be accompanied by the particular certificate for the system.

This certificate is based on the model forms shown in Appendix 6 of BS 7671.

Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

Please see the 'Notes for Recipients' on the reverse of this page.

## NOTES FOR RECIPIENT

**THIS SAFETY CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE**

**IF YOU WERE THE PERSON ORDERING THE WORK, BUT NOT THE OWNER OR USER OF THE INSTALLATION, YOU SHOULD PASS THIS CERTIFICATE, OR A FULL COPY OF IT INCLUDING THESE NOTES, IMMEDIATELY TO THE OWNER OR USER OF THE INSTALLATION.**

**This safety certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected, tested and verified in accordance with the national standard for the safety of electrical installations, British Standard 7671 (as amended) - *Requirements for Electrical Installations* (the IET Wiring Regulations).**

**Where, as will often be the case, the installation incorporates a residual current device (RCD), there should be a notice at or near the consumer unit stating that the device should be tested at quarterly intervals. For safety reasons, it is important that you carry out the test regularly.**

**Also for safety reasons, the complete electrical installation will need to be inspected and tested at appropriate intervals by a skilled person or persons competent in such work. NICEIC\* recommends that you engage the services of an Approved Contractor for this purpose. The maximum interval recommended before the next inspection is stated on Page 1 under *Next Inspection*. There should also be a notice at or near the consumer unit indicating when the inspection of the installation is next due.**

Only an NICEIC Approved Contractor or Conforming Body responsible for the construction of the electrical installation is authorised to issue this NICEIC certificate.

The Domestic Electrical Installation Certificate consists of at least four pages. The certificate is invalid if pages (containing schedules) are missing. The certificate has a printed seven-digit serial number which is traceable to the Approved Contractor to which it was supplied.

This certificate is intended to be issued for either the initial certification of a new electrical installation, or for new work associated with an alteration or addition to an existing electrical installation, in a single dwelling (house or individual flat). For new electrical installation work in other than a single dwelling, a full Electrical Installation Certificate should have been issued.

This certificate should not have been issued for reporting on the condition of an existing electrical installation. An Electrical Installation Condition Report or, where appropriate, a Domestic Electrical Installation Condition Report should be issued for such an inspection.

You should have received the certificate marked 'Original' and the Approved Contractor should have retained the certificate marked 'Duplicate'.

**The 'Original' certificate should be kept in a safe place and shown to any person inspecting or undertaking work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new owner or user that the electrical installation work complied with the requirements of the national electrical safety standard at the time the certificate was issued.**

Page 1 of this certificate provides details of the electrical installation, together with the names and signatures of the persons certifying the installation work and reviewing the results of inspection and testing on behalf of the Approved Contractor responsible for the work, details of which are also given on that page.

Certification provides an assurance that the electrical installation work has been fully inspected and tested, and that the work has been carried out in accordance with the requirements of BS 7671 (except for any departures recorded in the appropriate part of the certificate).

All unshaded boxes should have been completed either by insertion of the relevant details or by entering 'N/A', meaning 'Not Applicable', where appropriate.

Where the electrical work to which this certificate relates includes the provision of a mains powered fire detection and alarm system (such as one or more smoke alarms), this electrical safety certificate must be accompanied by a separate certificate for that system in accordance with British Standard BS 5839-6: 2013: *Fire detection and fire alarm systems for buildings - Part 6: Code of practice for the design, installation, commissioning and maintenance of fire detection and fire alarm systems in domestic premises*.

Should the person ordering the work (e.g. the client, as identified on Page 1 of this certificate) have reason to believe that any element of the electrical work for which the Approved Contractor has accepted responsibility (as indicated by the signatures on this certificate) does not comply with the requirements of the national electrical safety standard (BS 7671), the person should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application and from the website. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

\* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, the Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).

For further information about electrical safety and how NICEIC can help you, visit [www.niceic.com](http://www.niceic.com)



# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Original (To the person ordering the work)

SUPPLY CHARACTERISTICS				Tick boxes and enter details, as appropriate Nature of supply parameters				Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one supply, record the higher or highest values				Characteristics of primary supply overcurrent protective device(s)			
System type(s)		Number and type of live conductors		Number of sources		Nominal voltage(s)		Nominal frequency, $f^{(1)}$		External earth fault loop impedance, $Z_e^{(1)}$		BS(EN)		Short-circuit capacity	
TN-S	N/A	1-phase (2-wire)	<input checked="" type="checkbox"/>	1-phase (3-wire)	N/A	1	400 V	50	Hz	0.35	$\Omega$	BS 88-2 Fuse System E (bolted)	16	kA	
TN-C-S	<input checked="" type="checkbox"/>	3-phase (3-wire)	N/A	3-phase (4-wire)	N/A		$U_o^{(1)}$ 230 V					Type E	Confirmation of supply polarity	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	
TT	N/A	Other	Please state									Rated current	100	A	
				Single-phase Prospective fault current, $I_{pf}^{(2/3)}$		16 kA		3-phase Prospective fault current, $I_{pf}^{(2/3)}$		N/A kA					

PARTICULARS OF INSTALLATION AT THE ORIGIN				Tick boxes and enter details, as appropriate				Main Switch/Switch-Fuse/Circuit-Breaker/RCD							
Means of earthing		Details of installation earth electrode (where applicable)		Protective measure(s) for fault protection		Measured $Z_e$		Type BS(EN)		Voltage rating		RCD operating current, $I_{\Delta n}^*$		RCD operating time (at $I_{\Delta n}^*$ )	
Distributor's facility	<input checked="" type="checkbox"/>	Type (eg rod(s), tape etc)	N/A	Location		ADS	$\Omega$	BS EN 60947-3 Isolator	230	V	2	N/A	N/A	ms	
Installation earth electrode	N/A	Electrode resistance, $R_A$	$\Omega$	Method of measurement				No of poles	80	A					
Earthing conductor		Main protective bonding conductors and bonding of extraneous-conductive-parts (✓)		Water installation pipes		Structural steel		Supply conductors material		RCD operating time (at $I_{\Delta n}^*$ )		Rated time delay*			
Conductor material	copper	Continuity/connection verified	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	Conductor material	copper	<input checked="" type="checkbox"/>	N/A	copper	25	mm <sup>2</sup>	N/A	ms	N/A	ms	
Conductor csa	16 mm <sup>2</sup>	Continuity/connection verified	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	Conductor csa	10 mm <sup>2</sup>	<input checked="" type="checkbox"/>		Oil installation pipes							
		Location (where not obvious)		Gas installation pipes											

\* applicable only where an RCD is used as a main circuit-breaker

SCHEDULE OF ITEMS INSPECTED		† See note below	
<b>1.0 CONDITION/ADEQUACY OF DISTRIBUTOR'S/SUPPLY INTAKE EQUIPMENT (the Distributor should be notified of any unsatisfactory equipment)</b>			
1.1	Service cable	<input checked="" type="checkbox"/>	
1.2	Service head	<input checked="" type="checkbox"/>	
1.3	Distributor's earthing arrangement	<input checked="" type="checkbox"/>	
1.4	Meter tails - Distributor/Consumer	<input checked="" type="checkbox"/>	
1.5	Metering equipment	<input checked="" type="checkbox"/>	
1.6	Means of main isolation (where present)	<input checked="" type="checkbox"/>	
<b>2.0 PARALLEL OR SWITCHED ALTERNATIVE SOURCES OF SUPPLY</b>			
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
2.3	Presence of alternative/additional supply warning notice(s)	<input checked="" type="checkbox"/>	
<b>3.0 AUTOMATIC DISCONNECTION OF SUPPLY</b>			
3.1	Presence and adequacy of protective earthing/ bonding arrangements as follows:		
a)	Distributor's earthing arrangement or installation earth electrode arrangement	N/A	
b)	Earthing conductor and connections	<input checked="" type="checkbox"/>	
c)	Main protective bonding conductors and connections	<input checked="" type="checkbox"/>	
d)	Earthing/bonding labels at all appropriate locations	<input checked="" type="checkbox"/>	
<b>3.2 Accessibility of:</b>			
a)	Earthing conductor connections	<input checked="" type="checkbox"/>	
b)	All protective bonding connections	<input checked="" type="checkbox"/>	
<b>4.0 BASIC PROTECTION</b>			
4.1	Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:		
a)	Insulation of live parts e.g. conductors completely covered with durable insulating materials	<input checked="" type="checkbox"/>	
b)	Barriers or enclosures e.g. correct IP rating	<input checked="" type="checkbox"/>	
<b>5.0 ADDITIONAL PROTECTION</b>			
5.1	Presence and effectiveness of additional protection methods		
a)	RCD(s) not exceeding 30 mA operating current	<input checked="" type="checkbox"/>	
b)	Supplementary bonding	<input checked="" type="checkbox"/>	
<b>6.0 OTHER METHODS OF PROTECTION</b>			
6.1	Basic and fault protection		LOCATION
a)	SELV	<input checked="" type="checkbox"/>	
b)	PELV	<input checked="" type="checkbox"/>	
c)	Double insulation/Reinforced insulation	<input checked="" type="checkbox"/>	
d)	Electrical separation for one item of equipment	<input checked="" type="checkbox"/>	

† All boxes must be completed. ✓ indicates that an inspection was carried out and that the result was satisfactory. N/A indicates that an inspection was not applicable to the particular installation.

‡ Where a smoke alarm has been installed, separate certification is required on the appropriate form.

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Original (To the person ordering the work)

## SCHEDULE OF ITEMS INSPECTED <sup>† See note below</sup>

7.0 CONSUMER UNIT(S)	
7.1 Adequacy of working space/accessibility	✓
7.2 Security of fixing	✓
7.3 Adequacy / security of barriers	✓
7.4 Insulation of live parts not damaged during erection	✓
7.5 Enclosures not damaged during installation	✓
7.6 Suitability of enclosures for IP and fire ratings	✓
7.7 Presence and operation of main switch(es), linked, where appropriate	✓
7.8 Operation of circuit-breakers and RCDs to prove functionality	✓
7.9 Correct identification of circuit protective devices	✓
7.10 RCD(s) provided for fault protection, where specified	✓
7.11 RCD(s) provided for additional protection, where specified	✓
7.12 Confirmation overvoltage protection (SPDs) provided and functional where specified	✓
7.13 Presence of RCD quarterly test notice at or near the origin	✓
7.14 Presence of diagrams, charts or schedules at or near each Consumer unit(s)	✓
7.15 Presence of non-standard (mixed) cable colour warning notice at or near the appropriate distribution board, where required	N/A
7.16 Presence of next inspection recommendation label	✓
7.17 Presence of other required labelling	✓
7.18 Selection of protective device(s) and base(s); correct type and rating	✓
7.19 Single-pole protective devices in line conductor only	✓
7.20 Protection against mechanical damage where cables enter equipment	✓
7.21 Protection against electromagnetic effects where cables enter ferromagnetic enclosures	✓
7.22 Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓
8.0 CIRCUITS	
8.1 Identification of conductors	✓
8.2 Cables adequately supported throughout their length	✓
8.3 Examination of cables for signs of mechanical damage during installation	✓
8.4 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓
8.5 Adequacy of protective devices: type and rated current for fault protection	✓
8.6 Presence and adequacy of circuit protective conductors	✓
8.7 Coordination between conductors and overload protective devices	✓
8.8 Non-sheathed cables enclosed throughout (e.g. in conduit/trunking)	✓
8.9 Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage	✓
a) Installed in prescribed zones	✓
b) Incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like	✓

8.10 Provision of additional protection by RCDs having rated residual operating current ( $I_{\Delta n}$ ) not exceeding 30 mA	✓
a) For mobile equipment with a current rating not exceeding 32 A for use outdoors	✓
b) For all socket-outlets of rating 20 A or less, unless exempt	✓
c) For cables installed in walls/partitions at a depth of less than 50 mm	✓
d) For cables installed in walls/partitions containing metal parts regardless of depth	✓
8.11 Provision of fire barriers, sealing arrangements so as to minimize the spread of fire	✓
8.12 Band II cables segregated/separated from Band I cables	✓
8.13 Cables segregated/separated from non-electrical services	✓
8.14 Termination of cables at enclosures	✓
a) Connections under no undue strain	✓
b) No basic insulation of a conductor visible outside enclosure	✓
8.15 Circuit accessories not damaged during erection	✓
8.16 Single-pole devices for switching or protection in the line conductors only	✓
8.17 Adequacy of connections, including cpcs, within accessories and at fixed and stationary equipment	✓
8.18 Presence of appropriate devices for isolation and switching correctly located	✓
a) Accessible means of switching off for mechanical maintenance	✓
b) Correct operation verified (functional check)	✓

## 9.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)

9.1 Adequacy of working space/accessibility	✓
9.2 Suitability of equipment in terms of IP and fire ratings	✓
9.3 Enclosure not damaged/deteriorated during installation so as to impair safety	✓
9.4 Cable entry holes in ceilings above luminaires, sized or sealed so as to restrict the spread of fire	✓
9.5 Recessed luminaires (downlighters)	✓
a) Correct type of lamps fitted	✓
b) Installed to minimise build-up of heat	✓

## 10.0 LOCATION(S) CONTAINING A BATH OR SHOWER

10.1 Additional protection by RCD not exceeding 30 mA	✓
a) For low voltage circuits serving the location	✓
b) For low voltage circuits passing through Zone 1 and Zone 2 not serving the location	✓
10.2 Where used as a protective measure, requirements for SELV or PELV are met	✓
10.3 Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	✓
10.4 Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓
10.5 Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	✓
10.6 Suitability of equipment for external influences for installed location in terms of IP rating	✓
10.7 Suitability of electrical equipment for installation in a particular zone	✓

## 11.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS

11.1 List all other special installations or locations present, if any. (Record separately the results of particular inspections applied separately)


## SCHEDULE OF ITEMS INSPECTED BY:

Signature	Name (Capitals):	Date:
-----------	------------------	-------

<sup>†</sup> All boxes must be completed. ✓ indicates that an inspection was carried out and that the result was satisfactory. 'N/A' indicates that an inspection was not applicable to the particular installation.

<sup>‡</sup> Where a smoke alarm has been installed, separate certification is required on the appropriate form.

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

## CIRCUIT DETAILS TEST RESULTS

Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa		Max. disconnection time (s) by BS 7671	Overcurrent protective devices				RCD Operating current, I <sub>Δn</sub> (mA)	Maximum Z <sub>s</sub> permitted by BS 7671 (Ω)	Circuit impedances (Ω)				Insulation resistance				Polarity (✓)	Maximum measured earth fault loop impedance, Z <sub>s</sub> (Ω)	RCD			
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)		All circuits (At least one column to be completed)		Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)			at I <sub>Δn</sub> (ms)	at 5 I <sub>Δn</sub> (# applicable) (ms)	Test button operation (✓)	
														r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )										R <sub>2</sub>
*	Distribution Board	A	C	1	16	16	5	1361	1	63	16	N/A	N/A	N/A	N/A	N/A	0.21	N/A	20	20	20	✓	0.32	N/A	N/A	N/A	

Location of consumer unit	Main Incomer, basement	Designation of consumer unit	Isolating switch	Prospective fault current at consumer unit	0.446	kA
---------------------------	------------------------	------------------------------	------------------	--	-------	----

TEST INSTRUMENTS		Test instruments (serial numbers) used	
Multi-function		Insulation resistance	6007773
		Continuity	6007773
		Earth electrode resistance	
		Earth fault loop impedance	6006899
		RCD	6006899

A	Thermoplastic insulated/sheathed cables
B	Thermoplastic cables in non-metallic conduit
C	Thermoplastic cables in non-metallic conduit
D	Thermoplastic cables in non-metallic trunking
E	Thermoplastic cables in non-metallic trunking
F	Thermoplastic SWA cables
G	Thermoplastic SWA cables
H	Mixed metal cables
O	(Other - please state)

Original (To the person ordering the work)

CRN/ N/A

# SCHEDULES - CONTINUATION

CIRCUIT DETAILS													TEST RESULTS														
Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD		Circuit impedances (Ω)					Insulation resistance				RCD				
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I <sub>Δn</sub> (mA)	Maximum Z <sub>s</sub> permitted by BS 7671 (Ω)	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)	Polarity (✓)	Maximum measured earth fault loop impedance, Z <sub>s</sub> (Ω)	operating times		Test button operation (✓)
														r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	R <sub>1</sub> + R <sub>2</sub>	R <sub>2</sub>							at I <sub>Δn</sub> (ms)	at 5 I <sub>Δn</sub> (if applicable) (ms)	
*	Distribution Board	A	C	1	16	16	5	1361	1	63	16	N/A	N/A	N/A	N/A	0.21	N/A	20	20	20	✓	0.32	N/A	N/A	N/A		
1	Hob	A	102	1	6	2.5	0.4	60898	B	40	6	30	1.09	N/A	N/A	N/A	0.23	N/A	20	20	20	✓	0.32	45	19	N/A	
2	Sockets General	A	102	3	2.5	1.5	0.4	60898	B	32	6	30	1.36	0.12	0.12	0.19	0.3	N/A	20	20	20	✓	0.98	45	19	✓	
3	Fan & Door entry	A	102	2	2.5	1.5	0.4	60898	B	16	6	30	2.73	N/A	N/A	N/A	0.25	N/A	20	20	20	✓	0.45	45	19	✓	
4	Lights general	A	100	19	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	0.86	N/A	20	20	20	✓	1.09	45	19	✓	
5	SPARE																										
6	Sockets General	A	102	16	2.5	1.5	0.4	60898	B	32	6	30	1.36	0.64	0.64	0.92	0.43	N/A	20	20	20	✓	0.87				
7	Oven	A	102	1	2.5	1	0.4	60898	B	16	6	30	2.73	N/A	N/A	N/A	0.13	N/A	20	20	20	✓	0.48	45	19	✓	
8	Lights general	A	100	18	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	0.65	N/A	20	20	20	✓	0.87	45	20	✓	
9	Smoke detectors	A	100	2	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	0.46	N/A	20	20	20	✓	0.56	45	19	✓	
Location of consumer unit		KITCHEN			Designation of consumer unit		Distribution Board			Prospective fault current at consumer unit			0.446			kA											

TEST INSTRUMENTS		Test instruments (serial numbers) used									
Multi-function	Insulation resistance	6007773	Continuity	6007773	Earth electrode resistance		Earth fault loop impedance	6006899	RCD	6006899	

CODES FOR TYPE OF WIRING			
A	Thermoplastic sheathed cables		
B	Thermoplastic cables in metallic conduit		
C	Thermoplastic cables in non-metallic conduit		
D	Thermoplastic cables in metallic trunking		
E	Thermoplastic cables in non-metallic trunking		
F	Thermoplastic/SWA cables		
G	Thermosetting/SWA cables		
H	Mineral-insulated cables		
0 (Other - please state)			

# BUILDING REGULATIONS COMPLIANCE

## This is a Building Regulations Compliance Certificate:

It confirms the work detailed below has been carried out by a Gas Safe registered business. It is also confirmation from the business that the work:

- was carried out in accordance with the Gas Safety (Installation and Use) Regulations, as well as all other relevant industry standards
- has been self certified as being compliant with Section 4 and 7 of the Building Regulations in England, Wales and Isle of Man. This certificate is evidence, but not conclusive evidence, that the requirements of the building regulations have been complied with.

It is a legal requirement for anyone carrying out gas work on your behalf to be Gas Safe registered, please remember to check your engineer's licence card before you have any gas work carried out.

Registered businesses can self certify that their work complies with building regulations requirements in England, Wales and Isle of Man. This assists you in complying with your obligation to notify your local authority building control as the property owner, and this certificate confirms this notification has been done for you.

Thank you for using a Gas Safe registered business. Gas Safe Register recommends that you have your gas appliances checked for safety annually.

### Property Address:

3  
Flat 1-2 Badbrook Hall  
STROUD  
GL5 3BZ

Certificate No. 13070388

## Gas Safe Register has been notified that the work detailed below has been undertaken.

### Work completed by:

Mr Peter Stephen Hall

### On behalf of:

Swan Plumbing & Heating Ltd

### Registration Number:

184638

### Date of work:

20-06-2014

Install a gas-fired boiler  
Worcester Greenstar Junior 24i

Gas Safe Register®  
PO Box 6804  
Basingstoke RG24 4NB


[www.GasSafeRegister.co.uk](http://www.GasSafeRegister.co.uk)

**Gas Safe Register has notified your local authority building control of the work detailed on this certificate.**

Gas Safe Register inspects the work of registered businesses to ensure safety and standards are maintained.

Should your property be selected for inspection your co-operation in gaining access to inspect the work will be appreciated.

Please note that the contract for the work carried out is between yourself and the named business. Gas Safe Register can take no responsibility for the standard of work carried out. However, if you have any concerns regarding gas safety please contact your engineer.



# ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with *British Standard 7671 – Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable, LU5 5ZX

Original (To the person ordering the work)

DETAILS OF THE CLIENT			
Client / Address:	David Micheal Bath Street, Stroud, Gloucestershire		GL5 3BZ
DETAILS OF THE INSTALLATION			The installation is:
Address:	Flat 3, Badbrook Hall, Bath Street., Stroud, Gloucestershire	GL3 5BZ	New <input checked="" type="checkbox"/>
Extent of the installation covered by this certificate:	Fixed wiring only		An addition <input type="checkbox"/> An alteration <input type="checkbox"/>
DESIGN			
I/We, being the person(s) responsible for the design of the electrical installation (as indicated by my/our signature(s) below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, hereby CERTIFY that the design work for which I/we have been responsible is, to the best of my/our knowledge and belief, in accordance with BS 7671 amended to (date) except for the departures, if any, detailed as follows:			
Details of departures from BS 7671, as amended (Regulations 120.3, 133.5):			
The extent of liability of the signatory/signatories is limited to the work described above as the subject of this certificate.			
For the <b>DESIGN</b> of the installation: <span style="float: right;">**(Where there is divided responsibility for the design)</span>			
Signature	Date	Name (CAPITALS)	Designer 1
Signature	Date	Name (CAPITALS)	** Designer 2
CONSTRUCTION			
I/We, being the person(s) responsible for the construction of the electrical installation (as indicated by my/our signature below), particulars of which are described above, having exercised reasonable skill and care when carrying out the construction, hereby CERTIFY that the construction work for which I/we have been responsible is, to the best of my/our knowledge and belief, in accordance with BS 7671 amended to (date) except for the the departures, if any, detailed as follows:			
Details of departures from BS 7671, as amended (Regulations 120.3, 133.5):			
The extent of liability of the signatory is limited to the work described above as the subject of this certificate.			
For the <b>CONSTRUCTION</b> of the installation:			
Signature	Date	Name (CAPITALS)	Constructor
INSPECTION AND TESTING			
I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby CERTIFY that the work for which I/we have been responsible is to the best of my/our knowledge and belief in accordance with BS 7671, amended to (date) except for the departures, if any, detailed as follows:			
Details of departures from BS 7671, as amended (Regulations 120.3, 133.5):			
The extent of liability of the signatory/signatories is limited to the work described above as the subject of this certificate.			
For the <b>INSPECTION AND TESTING</b> of the installation:			
Signature	Date	Signature	Reviewed by
Name (CAPITALS)	Inspector	Name (CAPITALS)	Qualified Supervisor †
DESIGN, CONSTRUCTION, INSPECTION AND TESTING *			
* This box to be completed only where the design, construction, inspection and testing have been the responsibility of one person.			
I, being the person responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671, amended to (date) except for the departures, if any, detailed as follows:			
Details of departures from BS 7671, as amended (Regulations 120.3, 133.5): None			
The extent of liability of the signatory is limited to the work described above as the subject of this certificate.			
For the <b>DESIGN</b> , the <b>CONSTRUCTION</b> and the <b>INSPECTION AND TESTING</b> of the installation:			
Signature	Date 14/07/2014	Signature	Reviewed by
Name (CAPITALS) K M KEATES		Name (CAPITALS)	Qualified Supervisor ††

† Where the inspection and testing have been carried out by an Approved Contractor, the inspection and testing results are to be reviewed by the registered Qualified Supervisor.  
 †† Where the design, the construction, and the inspection and testing have been the responsibility of one person, the inspection and testing results are to be reviewed by the registered Qualified Supervisor.

Please see the 'Notes for Recipients' on the reverse of this page.

Check your certificate is genuine, go to [www.checkmyniceicert.com](http://www.checkmyniceicert.com) and put in the certificate number



37181MKPG/0966/387/00011  
THE CURRENT OCCUPIER  
FLAT 3 BADBROOK HALL  
BATH STREET  
STROUD  
GL5 3BZ



The Certificate of Compliance for your installation work has arrived. Please take time to read the document and the notes overleaf.

The Registered Installer named below has certified that the installation work detailed is compliant with Regulations 4 & 7 of The Building Regulations 2010 for England and Wales.

## Building Regulations Certificate of Compliance

Certificate Number:  
**9478389**

Date Completed:  
**14/07/2014**

Address of Installation:

**FLAT 3 BADBROOK HALL, BATH STREET, STROUD, GL5 3BZ**

Description of Notifiable Work:

**New full electrical installation (new build)**

Description of Location(s):

**Dwelling**

NICEIC Registered Installer:

**K M Keates Electrical Contracting L**  
**Registered no. 012209000**



This certificate is issued by NICEIC, a trading brand of Certsure LLP, as agent for and on behalf of the NICEIC registered installer named above. This certificate is evidence, but not conclusive evidence, that the requirements specified in the certificate have been complied with. NICEIC does not accept any responsibility for the content of this certificate or for the quality of work detailed, except under the NICEIC Platinum Promise described overleaf.

This certificate is a valuable document. Please retain it in a safe place. If this is not an original certificate or if there is any doubt to its authenticity, visit [www.checkmynotification.com](http://www.checkmynotification.com)

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with *British Standard 7671 – Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZK

CRN/ N/A Contractor's Reference Number

## DETAILS OF THE CLIENT

Client and address  
 Mr. D.Michael  
 Bath Street  
 Stroud  
 Gloucestershire  
 Postcode GL5 3BZ

## ADDRESS OF THE INSTALLATION

Installation address  
 Flat 4,Bath Street  
 Stroud  
 Gloucestershire  
 Postcode GL5 3BZ

## DETAILS OF THE INSTALLATION

Extent of the installation work covered by this certificate  
 Fixed wiring only, Flat 4

The installation is  
 New   
 An addition --  
 An alteration --

## DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I, being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my signature adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671, 17th Edition amended to 2015 (date) except for the departures, if any, detailed as follows:  
 Details of departures from BS 7671, as amended (Regulations 120.3, 133.5)  
 None

The extent of liability of the signatory is limited to the work described above as the subject of this certificate. For the **DESIGN**, the **CONSTRUCTION** and the **INSPECTION AND TESTING** of the installation

Signature  Name (CAPITALS) KEVIN KEATES Date 21/07/2015

### The results of the inspection and testing reviewed by the Qualified Supervisor

Signature  Name (CAPITALS) KEVIN KEATES Date 21/07/2015

## PARTICULARS OF THE APPROVED CONTRACTOR

Trading title  
 K M Keates Electrical Contracting L

Address  
 Manor Farm House  
 Gloucester

Telephone No 07831 695185 Postcode GL2 5JU

NICEIC Enrolment No (Essential information) 0 1 2 2 0 9 Branch No (if applicable) 0 0 0

## NEXT INSPECTION

§ Enter interval in terms of years, months or weeks, as appropriate

I RECOMMEND that this installation is further inspected and tested after an interval of not more than 10 years

## COMMENTS ON EXISTING INSTALLATION

Note: Enter 'NONE' or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation

None

In the case of an alteration or additions see Section 633 of BS 7671

## SCHEDULE OF ADDITIONAL RECORDS\*

See attached schedule

\* Where the electrical work to which this certificate relates includes the installation of a fire detection/ alarm system (or a part of such a system), this electrical safety certificate should be accompanied by the particular certificate for the system.

This certificate is based on the model forms shown in Appendix 6 of BS 7671.

Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)



## NOTES FOR RECIPIENT

**THIS SAFETY CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE**

**IF YOU WERE THE PERSON ORDERING THE WORK, BUT NOT THE OWNER OR USER OF THE INSTALLATION, YOU SHOULD PASS THIS CERTIFICATE, OR A FULL COPY OF IT INCLUDING THESE NOTES, IMMEDIATELY TO THE OWNER OR USER OF THE INSTALLATION.**

**This safety certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected, tested and verified in accordance with the national standard for the safety of electrical installations, British Standard 7671 (as amended) - *Requirements for Electrical Installations* (the IET Wiring Regulations).**

**Where, as will often be the case, the installation incorporates a residual current device (RCD), there should be a notice at or near the consumer unit stating that the device should be tested at quarterly intervals. For safety reasons, it is important that you carry out the test regularly.**

**Also for safety reasons, the complete electrical installation will need to be inspected and tested at appropriate intervals by a skilled person or persons competent in such work. NICEIC\* recommends that you engage the services of an Approved Contractor for this purpose. The maximum interval recommended before the next inspection is stated on Page 1 under *Next Inspection*. There should also be a notice at or near the consumer unit indicating when the inspection of the installation is next due.**

Only an NICEIC Approved Contractor or Conforming Body responsible for the construction of the electrical installation is authorised to issue this NICEIC certificate.

The Domestic Electrical Installation Certificate consists of at least four pages. The certificate is invalid if pages (containing schedules) are missing. The certificate has a printed seven-digit serial number which is traceable to the Approved Contractor to which it was supplied.

This certificate is intended to be issued for either the initial certification of a new electrical installation, or for new work associated with an alteration or addition to an existing electrical installation, in a single dwelling (house or individual flat). For new electrical installation work in other than a single dwelling, a full Electrical Installation Certificate should have been issued.

This certificate should not have been issued for reporting on the condition of an existing electrical installation. An Electrical Installation Condition Report or, where appropriate, a Domestic Electrical Installation Condition Report should be issued for such an inspection.

You should have received the certificate marked 'Original' and the Approved Contractor should have retained the certificate marked 'Duplicate'.

**The 'Original' certificate should be kept in a safe place and shown to any person inspecting or undertaking work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new owner or user that the electrical installation work complied with the requirements of the national electrical safety standard at the time the certificate was issued.**

Page 1 of this certificate provides details of the electrical installation, together with the names and signatures of the persons certifying the installation work and reviewing the results of inspection and testing on behalf of the Approved Contractor responsible for the work, details of which are also given on that page.

Certification provides an assurance that the electrical installation work has been fully inspected and tested, and that the work has been carried out in accordance with the requirements of BS 7671 (except for any departures recorded in the appropriate part of the certificate).

All unshaded boxes should have been completed either by insertion of the relevant details or by entering 'N/A', meaning 'Not Applicable', where appropriate.

Where the electrical work to which this certificate relates includes the provision of a mains powered fire detection and alarm system (such as one or more smoke alarms), this electrical safety certificate must be accompanied by a separate certificate for that system in accordance with British Standard BS 5839-6: 2013: *Fire detection and fire alarm systems for buildings - Part 6: Code of practice for the design, installation, commissioning and maintenance of fire detection and fire alarm systems in domestic premises*.

Should the person ordering the work (e.g. the client, as identified on Page 1 of this certificate) have reason to believe that any element of the electrical work for which the Approved Contractor has accepted responsibility (as indicated by the signatures on this certificate) does not comply with the requirements of the national electrical safety standard (BS 7671), the person should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application and from the website. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

*\* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, the Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).*

For further information about electrical safety and how NICEIC can help you,  
**visit [www.niceic.com](http://www.niceic.com)**

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Original (To the person ordering the work)

SUPPLY CHARACTERISTICS		Tick boxes and enter details, as appropriate				Nature of supply parameters				Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one supply, record the higher or highest values				Characteristics of primary supply overcurrent protective device(s)			
System type(s)		Number and type of live conductors		Number of sources		Nominal voltage(s)		Nominal frequency, $f^{(1)}$		External earth fault loop impedance, $Z_e^{(1)}$		BS(EN)		Short-circuit capacity			
TN-S	N/A	1-phase (2-wire)	<input checked="" type="checkbox"/>	1-phase (3-wire)	N/A	1	400 V	50	Hz	0.35	$\Omega$	88-2	16	kA			
TN-C-S	<input checked="" type="checkbox"/>	3-phase (3-wire)	N/A	3-phase (4-wire)	N/A		$U_o^{(1)}$ 230 V					Type E	Confirmation of supply polarity	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>			
TT	N/A	Other <small>Please state</small>		Single-phase Prospective fault current, $I_{pf}^{(2/3)}$		3-phase Prospective fault current, $I_{pf}^{(2/3)}$		Rated current				100 A					

PARTICULARS OF INSTALLATION AT THE ORIGIN				Tick boxes and enter details, as appropriate				Main Switch/Switch-Fuse/Circuit-Breaker/RCD			
Means of earthing		Details of installation earth electrode (where applicable)		Protective measure(s) for fault protection		Measured $Z_e$		Type BS(EN)		Voltage rating	
Distributor's facility	<input checked="" type="checkbox"/>	Type (eg rod(s), tape etc)	N/A	Location		ADS	$\Omega$	BS EN 60947-3 Isolator	230	V	
Installation earth electrode	N/A	Electrode resistance, $R_A$	$\Omega$	Method of measurement				No of poles	2	Rated current, $I_n$	100 A
Earthing conductor		Main protective bonding conductors and bonding of extraneous-conductive-parts (✓)		Water installation pipes		Structural steel		Supply conductors material		RCD operating current, $I_{\Delta n}^*$	
Conductor material	copper	Continuity/connection verified	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	Conductor material	copper	Conductor csa	10 mm <sup>2</sup>	N/A	copper	N/A	mA
Conductor csa	16 mm <sup>2</sup>	Continuity/connection verified	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	Location (where not obvious)				Supply conductors csa	25 mm <sup>2</sup>	RCD operating time (at $I_{\Delta n}^*$ )	N/A ms
										Rated time delay*	N/A ms

\* applicable only where an RCD is used as a main circuit-breaker

SCHEDULE OF ITEMS INSPECTED		† See note below	
<b>1.0 CONDITION/ADEQUACY OF DISTRIBUTOR'S/SUPPLY INTAKE EQUIPMENT (the Distributor should be notified of any unsatisfactory equipment)</b>			
1.1	Service cable	<input checked="" type="checkbox"/>	
1.2	Service head	<input checked="" type="checkbox"/>	
1.3	Distributor's earthing arrangement	<input checked="" type="checkbox"/>	
1.4	Meter tails - Distributor/Consumer	<input checked="" type="checkbox"/>	
1.5	Metering equipment	<input checked="" type="checkbox"/>	
1.6	Means of main isolation (where present)	<input checked="" type="checkbox"/>	
<b>2.0 PARALLEL OR SWITCHED ALTERNATIVE SOURCES OF SUPPLY</b>			
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
2.3	Presence of alternative/additional supply warning notice(s)	<input checked="" type="checkbox"/>	
<b>3.0 AUTOMATIC DISCONNECTION OF SUPPLY</b>			
3.1	Presence and adequacy of protective earthing/ bonding arrangements as follows:		
a)	Distributor's earthing arrangement or installation earth electrode arrangement	N/A	
b)	Earthing conductor and connections	<input checked="" type="checkbox"/>	
c)	Main protective bonding conductors and connections	<input checked="" type="checkbox"/>	
d)	Earthing/bonding labels at all appropriate locations	<input checked="" type="checkbox"/>	
3.2	Accessibility of:		
a)	Earthing conductor connections	<input checked="" type="checkbox"/>	
b)	All protective bonding connections	<input checked="" type="checkbox"/>	
<b>4.0 BASIC PROTECTION</b>			
4.1	Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:		
a)	Insulation of live parts e.g. conductors completely covered with durable insulating materials	<input checked="" type="checkbox"/>	
b)	Barriers or enclosures e.g. correct IP rating	<input checked="" type="checkbox"/>	
<b>5.0 ADDITIONAL PROTECTION</b>			
5.1	Presence and effectiveness of additional protection methods		
a)	RCD(s) not exceeding 30 mA operating current	<input checked="" type="checkbox"/>	
b)	Supplementary bonding	<input checked="" type="checkbox"/>	
<b>6.0 OTHER METHODS OF PROTECTION</b>			
6.1	Basic and fault protection		LOCATION
a)	SELV	N/A	
b)	PELV	<input checked="" type="checkbox"/>	
c)	Double insulation/Reinforced insulation	<input checked="" type="checkbox"/>	
d)	Electrical separation for one item of equipment	<input checked="" type="checkbox"/>	

† All boxes must be completed. ✓ indicates that an inspection was carried out and that the result was satisfactory. 'N/A' indicates that an inspection was not applicable to the particular installation.

‡ Where a smoke alarm has been installed, separate certification is required on the appropriate form.

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Original (To the person ordering the work)

SCHEDULE OF ITEMS INSPECTED <sup>† See note below</sup>	
<b>7.0 CONSUMER UNIT(S)</b>	
7.1 Adequacy of working space/accessibility	✓
7.2 Security of fixing	✓
7.3 Adequacy / security of barriers	✓
7.4 Insulation of live parts not damaged during erection	✓
7.5 Enclosures not damaged during installation	✓
7.6 Suitability of enclosures for IP and fire ratings	✓
7.7 Presence and operation of main switch(es), linked, where appropriate	✓
7.8 Operation of circuit-breakers and RCDs to prove functionality	✓
7.9 Correct identification of circuit protective devices	✓
7.10 RCD(s) provided for fault protection, where specified	✓
7.11 RCD(s) provided for additional protection, where specified	✓
7.12 Confirmation overvoltage protection (SPDs) provided and functional where specified	✓
7.13 Presence of RCD quarterly test notice at or near the origin	✓
7.14 Presence of diagrams, charts or schedules at or near each Consumer unit(s)	✓
7.15 Presence of non-standard (mixed) cable colour warning notice at or near the appropriate distribution board, where required	N/A
7.16 Presence of next inspection recommendation label	✓
7.17 Presence of other required labelling	N/A
7.18 Selection of protective device(s) and base(s); correct type and rating	✓
7.19 Single-pole protective devices in line conductor only	✓
7.20 Protection against mechanical damage where cables enter equipment	✓
7.21 Protection against electromagnetic effects where cables enter ferromagnetic enclosures	✓
7.22 Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓
<b>8.0 CIRCUITS</b>	
8.1 Identification of conductors	✓
8.2 Cables adequately supported throughout their length	✓
8.3 Examination of cables for signs of mechanical damage during installation	✓
8.4 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓
8.5 Adequacy of protective devices: type and rated current for fault protection	✓
8.6 Presence and adequacy of circuit protective conductors	✓
8.7 Coordination between conductors and overload protective devices	✓
8.8 Non-sheathed cables enclosed throughout (e.g. in conduit/trunking)	N/A
8.9 Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage	
a) Installed in prescribed zones	✓
b) Incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like	✓
<b>8.10 Provision of additional protection by RCDs having rated residual operating current (<math>I_{\Delta n}</math>) not exceeding 30 mA</b>	
a) For mobile equipment with a current rating not exceeding 32 A for use outdoors	✓
b) For all socket-outlets of rating 20 A or less, unless exempt	✓
c) For cables installed in walls/partitions at a depth of less than 50 mm	✓
d) For cables installed in walls/partitions containing metal parts regardless of depth	✓
8.11 Provision of fire barriers, sealing arrangements so as to minimize the spread of fire	✓
8.12 Band II cables segregated/separated from Band I cables	✓
8.13 Cables segregated/separated from non-electrical services	✓
8.14 Termination of cables at enclosures	
a) Connections under no undue strain	✓
b) No basic insulation of a conductor visible outside enclosure	✓
8.15 Circuit accessories not damaged during erection	✓
8.16 Single-pole devices for switching or protection in the line conductors only	✓
8.17 Adequacy of connections, including cpcs, within accessories and at fixed and stationary equipment	✓
8.18 Presence of appropriate devices for isolation and switching correctly located	
a) Accessible means of switching off for mechanical maintenance	✓
b) Correct operation verified (functional check)	✓
<b>9.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)</b>	
9.1 Adequacy of working space/accessibility	✓
9.2 Suitability of equipment in terms of IP and fire ratings	✓
9.3 Enclosure not damaged/deteriorated during installation so as to impair safety	✓
9.4 Cable entry holes in ceilings above luminaires, sized or sealed so as to restrict the spread of fire	✓
9.5 Recessed luminaires (downlighters)	
a) Correct type of lamps fitted	✓
b) Installed to minimise build-up of heat	✓
<b>10.0 LOCATION(S) CONTAINING A BATH OR SHOWER</b>	
10.1 Additional protection by RCD not exceeding 30 mA	
a) For low voltage circuits serving the location	✓
b) For low voltage circuits passing through Zone 1 and Zone 2 not serving the location	✓
10.2 Where used as a protective measure, requirements for SELV or PELV are met	✓
10.3 Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	✓
10.4 Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓
10.5 Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	✓
10.6 Suitability of equipment for external influences for installed location in terms of IP rating	✓
10.7 Suitability of electrical equipment for installation in a particular zone	✓
<b>11.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS</b>	
11.1 List all other special installations or locations present, if any. (Record separately the results of particular inspections applied separately)	

**SCHEDULE OF ITEMS INSPECTED BY:**

Signature  Name (Capitals): KEVIN KEATES Date: 21/07/2015

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

## CIRCUIT DETAILS TEST RESULTS

Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa		Max. disconnection time (s) by BS 7671	Overcurrent protective devices				RCD Operating current, I <sub>Δn</sub> (mA)	Maximum Z <sub>s</sub> permitted by BS 7671 (Ω)	Circuit impedances (Ω)					Insulation resistance				Polarity (✓)	Maximum measured earth fault loop impedance, Z <sub>s</sub> (Ω)	RCD									
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)			operating times at I <sub>Δn</sub> (ms)	Test button operation at 5 I <sub>Δn</sub> (if applicable) (ms)								
														r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )	R <sub>2</sub>																
					*																													
	Distribution Board	A	C	1	16	16	5	1361	2	63	16	N/A	N/A	N/A	N/A	N/A	0.18	N/A	N/A	20	20	20	✓	0.29	N/A	N/A	N/A							

Location of consumer unit: **Main Incomer, Basement** Designation of consumer unit: **Isolating Switch** Prospective fault current at consumer unit: **0.746** kA

TEST INSTRUMENTS		Test instruments (serial numbers) used	
Multi-function		Insulation resistance	6007773
		Continuity	6007773
		Earth electrode resistance	
		Earth fault loop impedance	6006899
		RCD	6006899

CODES FOR TYPE OF WIRING	
A	Thermoplastic insulated/sheathed cables
B	Thermoplastic cables in non-metallic conduit
C	Thermoplastic cables in non-metallic conduit
D	Thermoplastic cables in non-metallic trunking
E	Thermoplastic cables in non-metallic trunking
F	Thermoplastic SWA cables
G	Thermosetting SWA cables
H	Mixed metal cables
O	(Other - please state)

Original (To the person ordering the work)

# SCHEDULES - CONTINUATION

CIRCUIT DETAILS											TEST RESULTS																							
Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD	Maximum $Z_s$ permitted by BS 7671 ( $\Omega$ )	Circuit impedances ( $\Omega$ )					Insulation resistance				Polarity	Maximum measured earth fault loop impedance, $Z_s$ ( $\Omega$ )	RCD									
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Operating current, $I_{\Delta n}$ (mA)	Ring final circuits only (measured end to end)			Line/Line	Line/Neutral	Line/Earth	Neutral/Earth	at $I_{\Delta n}$ (ms)			at 5 $I_{\Delta n}$ (if applicable) (ms)	Test button operation (✓)								
												$r_1$ (Line)			$r_n$ (Neutral)	$r_2$ (cpc)	$(R_1 + R_2)$										$R_2$	(M $\Omega$ )	(M $\Omega$ )	(M $\Omega$ )	(M $\Omega$ )			
					*																													
	Distribution Board	A	C	1	16	16	5	1361	2	63	16	N/A	N/A	N/A	N/A	N/A	0.18	N/A	N/A	20	20	20	✓	0.29	N/A	N/A	N/A							
1	Hob	A	102	1	6	2.5	0.4	60898	B	40	6	30	1.09	N/A	N/A	N/A	0.16	N/A	N/A	20	20	20	✓	0.64	73	20	✓							
2	Sockets General	A	102	14	2.5	1.5	0.4	60898	B	32	6	30	1.36	0.58	0.58	0.96	0.46	N/A	N/A	20	20	20	✓	0.99	73	20	✓							
3	Smoke detectors	A	102	2	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	0.45	N/A	N/A	20	20	20	✓	0.97	73	20	✓							
4	SPARE																																	
5	SPARE																																	
6	SPARE																																	
7	Oven	A	102	1	2.5	1.5	0.4	60898	B	16	6	30	2.73	N/A	N/A	N/A	0.25	N/A	N/A	20	20	20	✓	0.78	36	20	✓							
8	Sockets	A	102	1	2.5	1.5	0.4	60898	B	16	6	30	2.73	N/A	N/A	N/A	0.23	N/A	N/A	20	20	20	✓	0.65	36	20	✓							
9	Lights general	A	102	20	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	0.68	N/A	N/A	20	20	20	✓	1.02	36	20	✓							
Location of consumer unit		Kitchen						Designation of consumer unit		Distribution Board						Prospective fault current at consumer unit			0.746				kA											

TEST INSTRUMENTS		Test instruments (serial numbers) used								
Multi-function	Insulation resistance	6007773	Continuity	6007773	Earth electrode resistance		Earth fault loop impedance	6006899	RCD	6006899

CODES FOR TYPE OF WIRING			
A	B	C	D
Thermoplastic sheathed cables	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in non-metallic trunking	Thermoplastic cables in metallic trunking
F	G	H	0 (Other - please state)
Thermoplastic SWA cables	Thermosetting SWA cables	Mineral-insulated cables	

Original (To the person ordering the work)



APPROVED CONTRACTOR

This safety certificate is an important and valuable document which should be retained for future reference

This certificate is not valid if the serial number has been defaced or altered

DCN7C/

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with *British Standard 7671 – Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

CRN/N/A

Contractor's Reference Number

## DETAILS OF THE CLIENT

Client and address  
Mr. D. Michael  
Bath Street  
Stroud  
Gloucestershire

Postcode GL5 3BZ

## ADDRESS OF THE INSTALLATION

Installation address  
Flat 5, Bath Street  
Stroud  
Gloucestershire

Postcode GL5 3BZ

## DETAILS OF THE INSTALLATION

Extent of the installation work covered by this certificate  
Fixed wiring only, Flat 5

The installation is  
New   
An addition --  
An alteration --

## DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I, being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my signature adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671, 17th Edition amended to 2015 (date) except for the departures, if any, detailed as follows:

Details of departures from BS 7671, as amended (Regulations 120.3, 133.5)

None

The extent of liability of the signatory is limited to the work described above as the subject of this certificate. For the **DESIGN**, the **CONSTRUCTION** and the **INSPECTION AND TESTING** of the installation

Signature

Name (CAPITALS)

Date

The results of the inspection and testing reviewed by the Qualified Supervisor

Signature

Name (CAPITALS)

Date

## PARTICULARS OF THE APPROVED CONTRACTOR

Trading title  
K M Keates Electrical Contracting L

Address  
Manor Farm House  
Gloucester



Telephone No 07831 695185

Postcode GL2 5JU

NICEIC Enrolment No (Essential information) 0 1 2 2 0 9

Branch No (if applicable) 0 0 0

## NEXT INSPECTION

§ Enter interval in terms of years, months or weeks, as appropriate

I RECOMMEND that this installation is further inspected and tested after an interval of not more than 10 years

## COMMENTS ON EXISTING INSTALLATION

Note: Enter 'NONE' or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation

None

In the case of an alteration or additions see Section 633 of BS 7671

## SCHEDULE OF ADDITIONAL RECORDS\*

See attached schedule

\* Where the electrical work to which this certificate relates includes the installation of a fire detection/ alarm system (or a part of such a system), this electrical safety certificate should be accompanied by the particular certificate for the system.

This certificate is based on the model forms shown in Appendix 6 of BS 7671.

Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

Please see the 'Notes for Recipients' on the reverse of this page.

## NOTES FOR RECIPIENT

**THIS SAFETY CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE**

**IF YOU WERE THE PERSON ORDERING THE WORK, BUT NOT THE OWNER OR USER OF THE INSTALLATION, YOU SHOULD PASS THIS CERTIFICATE, OR A FULL COPY OF IT INCLUDING THESE NOTES, IMMEDIATELY TO THE OWNER OR USER OF THE INSTALLATION.**

**This safety certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected, tested and verified in accordance with the national standard for the safety of electrical installations, British Standard 7671 (as amended) - *Requirements for Electrical Installations* (the IET Wiring Regulations).**

**Where, as will often be the case, the installation incorporates a residual current device (RCD), there should be a notice at or near the consumer unit stating that the device should be tested at quarterly intervals. For safety reasons, it is important that you carry out the test regularly.**

**Also for safety reasons, the complete electrical installation will need to be inspected and tested at appropriate intervals by a skilled person or persons competent in such work. NICEIC\* recommends that you engage the services of an Approved Contractor for this purpose. The maximum interval recommended before the next inspection is stated on Page 1 under *Next Inspection*. There should also be a notice at or near the consumer unit indicating when the inspection of the installation is next due.**

Only an NICEIC Approved Contractor or Conforming Body responsible for the construction of the electrical installation is authorised to issue this NICEIC certificate.

The Domestic Electrical Installation Certificate consists of at least four pages. The certificate is invalid if pages (containing schedules) are missing. The certificate has a printed seven-digit serial number which is traceable to the Approved Contractor to which it was supplied.

This certificate is intended to be issued for either the initial certification of a new electrical installation, or for new work associated with an alteration or addition to an existing electrical installation, in a single dwelling (house or individual flat). For new electrical installation work in other than a single dwelling, a full Electrical Installation Certificate should have been issued.

This certificate should not have been issued for reporting on the condition of an existing electrical installation. An Electrical Installation Condition Report or, where appropriate, a Domestic Electrical Installation Condition Report should be issued for such an inspection.

You should have received the certificate marked 'Original' and the Approved Contractor should have retained the certificate marked 'Duplicate'.

**The 'Original' certificate should be kept in a safe place and shown to any person inspecting or undertaking work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new owner or user that the electrical installation work complied with the requirements of the national electrical safety standard at the time the certificate was issued.**

Page 1 of this certificate provides details of the electrical installation, together with the names and signatures of the persons certifying the installation work and reviewing the results of inspection and testing on behalf of the Approved Contractor responsible for the work, details of which are also given on that page.

Certification provides an assurance that the electrical installation work has been fully inspected and tested, and that the work has been carried out in accordance with the requirements of BS 7671 (except for any departures recorded in the appropriate part of the certificate).

All unshaded boxes should have been completed either by insertion of the relevant details or by entering 'N/A', meaning 'Not Applicable', where appropriate.

Where the electrical work to which this certificate relates includes the provision of a mains powered fire detection and alarm system (such as one or more smoke alarms), this electrical safety certificate must be accompanied by a separate certificate for that system in accordance with British Standard BS 5839-6: 2013: *Fire detection and fire alarm systems for buildings - Part 6: Code of practice for the design, installation, commissioning and maintenance of fire detection and fire alarm systems in domestic premises*.

Should the person ordering the work (e.g. the client, as identified on Page 1 of this certificate) have reason to believe that any element of the electrical work for which the Approved Contractor has accepted responsibility (as indicated by the signatures on this certificate) does not comply with the requirements of the national electrical safety standard (BS 7671), the person should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application and from the website. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

\* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, the Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).

For further information about electrical safety and how NICEIC can help you, visit [www.niceic.com](http://www.niceic.com)

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Original (To the person ordering the work)

SUPPLY CHARACTERISTICS			Tick boxes and enter details, as appropriate				Nature of supply parameters			Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one supply, record the higher or highest values			Characteristics of primary supply overcurrent protective device(s)			
System type(s)			Number and type of live conductors				Number of sources	Nominal voltage(s)		Nominal frequency, $f^{(1)}$		BS(EN)	Short-circuit capacity			
TN-S	N/A		1-phase (2-wire)	<input checked="" type="checkbox"/>	1-phase (3-wire)	N/A	1	400 V		50 Hz		BS 88-2 Fuse System E (bolted)	16 kA			
TN-C-S	<input checked="" type="checkbox"/>		3-phase (3-wire)	N/A	3-phase (4-wire)	N/A		$U_o^{(1)}$ 230 V		External earth fault loop impedance, $Z_e^{(1)}$	0.35 $\Omega$	Type	E	Confirmation of supply polarity	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
TT	N/A		Other	Please state								Rated current	100 A			
			Single-phase		Prospective fault current, $I_{pf}^{(2/3)}$		16 kA	3-phase		Prospective fault current, $I_{pf}^{(2/3)}$		N/A kA				

PARTICULARS OF INSTALLATION AT THE ORIGIN				Tick boxes and enter details, as appropriate								Main Switch/Switch-Fuse/Circuit-Breaker/RCD			
Means of earthing		Details of installation earth electrode (where applicable)						Measured $Z_e$							
Distributor's facility	N/A	Type (eg rod(s), tape etc)	N/A	Location				Protective measure(s) for fault protection	Maximum demand (Load)		Type BS(EN)	Voltage rating		230 V	
Installation earth electrode		Electrode resistance, $R_A$	$\Omega$	Method of measurement				ADS	Number of smoke alarms		No of poles	Rated current, $I_n$		80 A	
Earthing conductor		Main protective bonding conductors and bonding of extraneous-conductive-parts ( <input checked="" type="checkbox"/> )						Water installation pipes		<input checked="" type="checkbox"/>		Structural steel		N/A	
Conductor material	copper	Continuity/connection verified	<input checked="" type="checkbox"/>	Conductor material	copper	Conductor csa	10 mm <sup>2</sup>	Oil installation pipes	N/A	Other		Supply conductors material		copper	
Conductor csa	16 mm <sup>2</sup>	Continuity/connection verified	<input checked="" type="checkbox"/>	Location (where not obvious)				Gas installation pipes	<input checked="" type="checkbox"/>			Supply conductors csa		25 mm <sup>2</sup>	
												RCD operating current, $I_{\Delta n}^*$		N/A mA	
												RCD operating time (at $I_{\Delta n}^*$ )		N/A ms	
												Rated time delay*		N/A ms	

\* applicable only where an RCD is used as a main circuit-breaker

SCHEDULE OF ITEMS INSPECTED		† See note below	
<b>1.0 CONDITION/ADEQUACY OF DISTRIBUTOR'S/SUPPLY INTAKE EQUIPMENT (the Distributor should be notified of any unsatisfactory equipment)</b>			
1.1	Service cable	<input checked="" type="checkbox"/>	
1.2	Service head	<input checked="" type="checkbox"/>	
1.3	Distributor's earthing arrangement	<input checked="" type="checkbox"/>	
1.4	Meter tails - Distributor/Consumer	<input checked="" type="checkbox"/>	
1.5	Metering equipment	<input checked="" type="checkbox"/>	
1.6	Means of main isolation (where present)	<input checked="" type="checkbox"/>	
<b>2.0 PARALLEL OR SWITCHED ALTERNATIVE SOURCES OF SUPPLY</b>			
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply		N/A
2.2	Adequate arrangements where a generating set operates in parallel with the public supply		N/A
2.3	Presence of alternative/additional supply warning notice(s)	<input checked="" type="checkbox"/>	
<b>3.0 AUTOMATIC DISCONNECTION OF SUPPLY</b>			
3.1	Presence and adequacy of protective earthing/ bonding arrangements as follows:		
a)	Distributor's earthing arrangement or installation earth electrode arrangement	<input checked="" type="checkbox"/>	
b)	Earthing conductor and connections	<input checked="" type="checkbox"/>	
c)	Main protective bonding conductors and connections	<input checked="" type="checkbox"/>	
d)	Earthing/bonding labels at all appropriate locations	<input checked="" type="checkbox"/>	
3.2	Accessibility of:		
a)	Earthing conductor connections	<input checked="" type="checkbox"/>	
b)	All protective bonding connections	<input checked="" type="checkbox"/>	
<b>4.0 BASIC PROTECTION</b>			
4.1	Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:		
a)	Insulation of live parts e.g. conductors completely covered with durable insulating materials	<input checked="" type="checkbox"/>	
b)	Barriers or enclosures e.g. correct IP rating	<input checked="" type="checkbox"/>	
<b>5.0 ADDITIONAL PROTECTION</b>			
5.1	Presence and effectiveness of additional protection methods		
a)	RCD(s) not exceeding 30 mA operating current	<input checked="" type="checkbox"/>	
b)	Supplementary bonding	<input checked="" type="checkbox"/>	
<b>6.0 OTHER METHODS OF PROTECTION</b>			
6.1	Basic and fault protection		LOCATION
a)	SELV	<input checked="" type="checkbox"/>	
b)	PELV	<input checked="" type="checkbox"/>	
c)	Double insulation/Reinforced insulation	<input checked="" type="checkbox"/>	
d)	Electrical separation for one item of equipment	<input checked="" type="checkbox"/>	

† All boxes must be completed. ✓ indicates that an inspection was carried out and that the result was satisfactory. N/A indicates that an inspection was not applicable to the particular installation.

‡ Where a smoke alarm has been installed, separate certification is required on the appropriate form.



# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

## SCHEDULE OF ITEMS INSPECTED <sup>†</sup> See note below

7.0 CONSUMER UNIT(S)	
7.1 Adequacy of working space/accessibility	✓
7.2 Security of fixing	✓
7.3 Adequacy / security of barriers	✓
7.4 Insulation of live parts not damaged during erection	✓
7.5 Enclosures not damaged during installation	✓
7.6 Suitability of enclosures for IP and fire ratings	N/A
7.7 Presence and operation of main switch(es), linked, where appropriate	✓
7.8 Operation of circuit-breakers and RCDs to prove functionality	✓
7.9 Correct identification of circuit protective devices	✓
7.10 RCD(s) provided for fault protection, where specified	✓
7.11 RCD(s) provided for additional protection, where specified	✓
7.12 Confirmation overvoltage protection (SPDs) provided and functional where specified	N/A
7.13 Presence of RCD quarterly test notice at or near the origin	✓
7.14 Presence of diagrams, charts or schedules at or near each Consumer unit(s)	✓
7.15 Presence of non-standard (mixed) cable colour warning notice at or near the appropriate distribution board, where required	N/A
7.16 Presence of next inspection recommendation label	✓
7.17 Presence of other required labelling	✓
7.18 Selection of protective device(s) and base(s); correct type and rating	✓
7.19 Single-pole protective devices in line conductor only	✓
7.20 Protection against mechanical damage where cables enter equipment	✓
7.21 Protection against electromagnetic effects where cables enter ferromagnetic enclosures	✓
7.22 Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓
8.0 CIRCUITS	
8.1 Identification of conductors	✓
8.2 Cables adequately supported throughout their length	✓
8.3 Examination of cables for signs of mechanical damage during installation	✓
8.4 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓
8.5 Adequacy of protective devices: type and rated current for fault protection	✓
8.6 Presence and adequacy of circuit protective conductors	✓
8.7 Coordination between conductors and overload protective devices	✓
8.8 Non-sheathed cables enclosed throughout (e.g. in conduit/trunking)	✓
8.9 Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage	✓
a) Installed in prescribed zones	✓
b) Incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like	✓

8.10 Provision of additional protection by RCDs having rated residual operating current ( $I_{\Delta n}$ ) not exceeding 30 mA	
a) For mobile equipment with a current rating not exceeding 32 A for use outdoors	N/A
b) For all socket-outlets of rating 20 A or less, unless exempt	N/A
c) For cables installed in walls/partitions at a depth of less than 50 mm	✓
d) For cables installed in walls/partitions containing metal parts regardless of depth	✓
8.11 Provision of fire barriers, sealing arrangements so as to minimize the spread of fire	✓
8.12 Band II cables segregated/separated from Band I cables	✓
8.13 Cables segregated/separated from non-electrical services	✓
8.14 Termination of cables at enclosures	
a) Connections under no undue strain	✓
b) No basic insulation of a conductor visible outside enclosure	✓
8.15 Circuit accessories not damaged during erection	✓
8.16 Single-pole devices for switching or protection in the line conductors only	✓
8.17 Adequacy of connections, including cpcs, within accessories and at fixed and stationary equipment	✓
8.18 Presence of appropriate devices for isolation and switching correctly located	
a) Accessible means of switching off for mechanical maintenance	✓
b) Correct operation verified (functional check)	✓

## 9.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)

9.1 Adequacy of working space/accessibility	✓
9.2 Suitability of equipment in terms of IP and fire ratings	✓
9.3 Enclosure not damaged/deteriorated during installation so as to impair safety	✓
9.4 Cable entry holes in ceilings above luminaires, sized or sealed so as to restrict the spread of fire	✓
9.5 Recessed luminaires (downlighters)	
a) Correct type of lamps fitted	✓
b) Installed to minimise build-up of heat	✓

## 10.0 LOCATION(S) CONTAINING A BATH OR SHOWER

10.1 Additional protection by RCD not exceeding 30 mA	
a) For low voltage circuits serving the location	✓
b) For low voltage circuits passing through Zone 1 and Zone 2 not serving the location	✓
10.2 Where used as a protective measure, requirements for SELV or PELV are met	✓
10.3 Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	✓
10.4 Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓
10.5 Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	✓
10.6 Suitability of equipment for external influences for installed location in terms of IP rating	✓
10.7 Suitability of electrical equipment for installation in a particular zone	✓

## 11.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS

11.1 List all other special installations or locations present, if any. (Record separately the results of particular inspections applied separately)


## SCHEDULE OF ITEMS INSPECTED BY:

Signature: \_\_\_\_\_ Name (Capitals): \_\_\_\_\_ Date: \_\_\_\_\_

<sup>†</sup> All boxes must be completed. ✓ indicates that an inspection was carried out and that the result was satisfactory. 'N/A' indicates that an inspection was not applicable to the particular installation.

<sup>‡</sup> Where a smoke alarm has been installed, separate certification is required on the appropriate form.

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

## CIRCUIT DETAILS TEST RESULTS

Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa		Max. disconnection time (s) by BS 7671	Overcurrent protective devices				RCD Operating current, I <sub>Δn</sub> (mA)	Maximum Z <sub>s</sub> permitted by BS 7671 (Ω)	Circuit impedances (Ω)					Insulation resistance				Polarity (✓)	Maximum measured earth fault loop impedance, Z <sub>s</sub> (Ω)	RCD		
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)			at I <sub>Δn</sub> (ms)	at 5 I <sub>Δn</sub> (if applicable) (ms)	Test button operation (✓)
														r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )	R <sub>2</sub>									
1	Distribution Board	A	C		16	16	5	1361	2	63	16	N/A	N/A	N/A	N/A	0.23	N/A	20	20	20	✓	0.41	N/A	N/A	✓		

Location of consumer unit	Main Incomer-Basement	Designation of consumer unit	Isolating Switch	Prospective fault current at consumer unit	0.588	kA
---------------------------	-----------------------	------------------------------	------------------	--	-------	----

TEST INSTRUMENTS		Test instruments (serial numbers) used	
Multi-function		Insulation resistance	6007773
		Continuity	6007773
		Earth electrode resistance	
		Earth fault loop impedance	6006899
		RCD	6006899

A	Thermoplastic insulated/sheathed cables
B	Thermoplastic cables in non-metallic conduit
C	Thermoplastic cables in non-metallic conduit
D	Thermoplastic cables in metallic trunking
E	Thermoplastic cables in non-metallic trunking
F	Thermoplastic SWA cables
G	Thermoplastic SWA cables
H	Mixed metal cables
O	(Other - please state)

Original (To the person ordering the work)

**SCHEDULES - CONTINUATION**

CIRCUIT DETAILS												TEST RESULTS																	
Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD		Circuit impedances (Ω)					Insulation resistance				RCD						
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I <sub>Δn</sub> (mA)	Maximum Z <sub>s</sub> permitted by BS 7671 (Ω)	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)	Polarity (✓)	Maximum measured earth fault loop impedance, Z <sub>s</sub> (Ω)	operating times		Test button operation (✓)		
														r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )	R <sub>2</sub>							at I <sub>Δn</sub> (ms)	at 5 I <sub>Δn</sub> (if applicable) (ms)			
																	r <sub>1</sub>	r <sub>n</sub>	r <sub>2</sub>	(R <sub>1</sub> + R <sub>2</sub> )	R <sub>2</sub>	(MΩ)	(MΩ)	(MΩ)	(MΩ)	(Ω)	(ms)	(ms)	(✓)
*	Distribution Board	A	C	16	16	5	1361	2	63	16	N/A	N/A	N/A	N/A	0.23	N/A	20	20	20	✓	0.41	N/A	N/A	✓					
1	Hob	A	102	1	6	2.5	0.4	60898	B	40	6	30	1.09	N/A	N/A	N/A	0.16	N/A	20	20	20	✓	0.65	54	20	✓			
2	Sockets General	A	102	13	2.5	1.5	0.4	60898	B	32	6	30	1.36	0.46	0.46	0.66	0.31	N/A	N/A	20	20	20	✓	0.68	54	20	✓		
3	Lights general	A	100	15	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	N/A	0.78	N/A	20	20	20	✓	1.2	54	20	✓		
4	SPARE																												
5	SPARE																												
6	Sockets General	A	102	8	2.5	1.5	0.4	60898	B	32	6	30	1.36	0.47	0.47	0.69	0.38	N/A	N/A	20	20	20	✓	0.8	57	20	✓		
7	Lights general	A	100	15	1	1	0.4	60898	B	32	6	30	1.36	N/A	N/A	N/A	N/A	0.89	N/A	20	20	20	✓	1.12	57	20	✓		
8	Smoke detectors	A	100	3	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	N/A	0.87	N/A	20	20	20	✓	0.67	57	20	✓		
Location of consumer unit		Hallway					Designation of consumer unit		Distribution Board					Prospective fault current at consumer unit			0.588			kA									
<b>TEST INSTRUMENTS</b>												Test instruments (serial numbers) used																	
Multi-function		Insulation resistance		6007773		Continuity		6007773		Earth electrode resistance		6006899		Earth fault loop impedance		6006899		RCD											

**Original** (To the person ordering the work)  
**0** (Other, please state)  
**H** Mineral-insulated cables  
**G** Thermosetting SWA cables  
**F** Thermoplastic SWA cables  
**E** Thermoplastic cables in metallic trunking  
**D** Thermoplastic cables in metallic trunking  
**C** Thermoplastic cables in metallic conduit  
**B** Thermoplastic cables in metallic conduit  
**A** Thermoplastic sheathed cables

This safety certificate is an important and valuable document which should be retained for future reference

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with *British Standard 7671 – Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX



Original (To the person ordering the work)

DETAILS OF THE CLIENT	
Client and address	Mr. D. Micheal Bath Street Stroud Gloucestershire
	Postcode GL5 3BZ

ADDRESS OF THE INSTALLATION	
Installation address	Mr. D. Micheal Flat 6, Bath Street Stroud Gloucestershire
	Postcode GL5 3BZ

DETAILS OF THE INSTALLATION	
Extent of the installation work covered by this certificate	Fixed wiring only, Flat 6
	The installation is New <input checked="" type="checkbox"/> An addition <input type="checkbox"/> An alteration <input type="checkbox"/>

DESIGN, CONSTRUCTION, INSPECTION AND TESTING
I/we, being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my/our signature adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I/we have been responsible is, to the best of my/our knowledge and belief, in accordance with BS 7671, 17th Edition, amended to 2013-2 (date) except for the departures, if any, detailed as follows: Details of departures from BS 7671, as amended (Regulations 120.3, 133.5) 701.410.3.5,701414.4.5

The extent of liability of the signatory is limited to the work described above as the subject of this certificate. For the <b>DESIGN</b> , the <b>CONSTRUCTION</b> and the <b>INSPECTION AND TESTING</b> of the installation			
Signature		Name (CAPITALS)	KEVIN KEATES
		Date	20/07/2015
<b>The results of the inspection and testing reviewed by the Qualified Supervisor</b>			
Signature		Name (CAPITALS)	KEVIN KEATES
		Date	20/07/2015

PARTICULARS OF THE APPROVED CONTRACTOR	
Trading title	K M Keates Electrical Contracting L
Address	Manor Farm House Gloucester
Telephone No	07831 695185
Postcode	GL2 5JU
NICEIC Enrolment No (Essential information)	0 1 2 2 0 9
Branch No (if applicable)	0 0 0

NEXT INSPECTION
I RECOMMEND that this installation is further inspected and tested after an interval of not more than <sup>§</sup> 10 years

COMMENTS ON EXISTING INSTALLATION
Clients instructions-Heat recovery fan fitted into a recess in zone 1 of a bath tub  <i>Note: Enter 'NONE' or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation</i>  <i>In the case of an alteration or additions see Section 633 of BS 7671</i>

SCHEDULE OF ADDITIONAL RECORDS*
See attached schedule

\* Where the electrical work to which this certificate relates includes the installation of a fire alarm system and/or an emergency lighting system (or a part of such systems), this electrical safety certificate should be accompanied by the particular certificate(s) for the system(s).  
 This certificate is based on the model form shown in Appendix 6 of BS 7671.  
 Published by NICEIC, a part of the Ascortiva Group © Copyright The Electrical Safety Council (July 2011)

Please see the 'Notes for Recipients' on the reverse of this page.

Check your certificate is genuine, go to www.checkmyniceicert.com <http://www.checkmyniceicert.com> and put in the certificate number

## NOTES FOR RECIPIENT

**THIS SAFETY CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE**

**IF YOU WERE THE PERSON ORDERING THE WORK, BUT NOT THE OWNER OR USER OF THE INSTALLATION, YOU SHOULD PASS THIS CERTIFICATE, OR A FULL COPY OF IT INCLUDING THESE NOTES, IMMEDIATELY TO THE OWNER OR USER OF THE INSTALLATION.**

**This safety certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected, tested and verified in accordance with the national standard for the safety of electrical installations, British Standard 7671 (as amended) - *Requirements for Electrical Installations* (the IET Wiring Regulations).**

**Where, as will often be the case, the installation incorporates a residual current device (RCD), there should be a notice at or near the consumer unit stating that the device should be tested at quarterly intervals. For safety reasons, it is important that you carry out the test regularly.**

**Also for safety reasons, the complete electrical installation will need to be inspected and tested at appropriate intervals by a competent person. NICEIC\* recommends that you engage the services of an Approved Contractor for this purpose. The maximum interval recommended before the next inspection is stated on Page 1 under *Next Inspection*. There should also be a notice at or near the consumer unit indicating when the inspection of the installation is next due.**

Only an NICEIC Approved Contractor or Conforming Body responsible for the construction of the electrical installation is authorised to issue this NICEIC certificate.

The Domestic Electrical Installation Certificate consists of at least three pages. The certificate is invalid if the second or third pages (containing schedules) are missing. The certificate has a printed seven-digit serial number which is traceable to the Approved Contractor to which it was supplied.

This certificate is intended to be issued for either the initial certification of a new electrical installation, or for new work associated with an alteration or addition to an existing electrical installation, in a single dwelling (house or individual flat). For new electrical installation work in other than a single dwelling, a full Electrical Installation Certificate should have been issued.

This certificate should not have been issued for reporting on the condition of an existing electrical installation. An Electrical Installation Condition Report or, where appropriate, a Domestic Electrical Installation Condition Report should be issued for such an inspection.

You should have received the certificate marked 'Original' and the Approved Contractor should have retained the certificate marked 'Duplicate'.

**The 'Original' certificate should be kept in a safe place and shown to any person inspecting or undertaking work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new owner or user that the electrical installation work complied with the requirements of the national electrical safety standard at the time the certificate was issued.**

Page 1 of this certificate provides details of the electrical installation, together with the names and signatures of the persons certifying the installation work and reviewing the results of inspection and testing on behalf of the Approved Contractor responsible for the work, details of which are also given on that page.

Certification provides an assurance that the electrical installation work has been fully inspected and tested, and that the work has been carried out in accordance with the requirements of BS 7671 (except for any departures recorded in the appropriate part of the certificate).

All unshaded boxes should have been completed either by insertion of the relevant details or by entering 'N/A', meaning 'Not Applicable', where appropriate.

Where the electrical work to which this certificate relates includes the provision of a mains-powered fire detection and alarm system (such as one or more smoke alarms), this electrical safety certificate must be accompanied by a separate certificate for that system in accordance with British Standard 5839: Part 6 - *Code of Practice for the design, installation and maintenance of fire detection and fire alarm systems in dwellings*.

Should the person ordering the work (e.g. the client, as identified on Page 1 of this certificate) have reason to believe that any element of the electrical work for which the Approved Contractor has accepted responsibility (as indicated by the signatures on this certificate) does not comply with the requirements of the national electrical safety standard (BS 7671), the person should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application and from the website. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

*\* NICEIC is a part of the Ascertiva Group, a wholly owned subsidiary of The Electrical Safety Council. Under license from The Electrical Safety Council, NICEIC acts as the electrical contracting industry's independent voluntary body for electrical installation safety matters throughout the UK, and maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).*

For further information about electrical safety and how NICEIC can help you,  
**visit [www.niceic.com](http://www.niceic.com)**

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Original (To the person ordering the work)

SUPPLY CHARACTERISTICS		Tick boxes and enter details, as appropriate		Nature of supply parameters		Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one supply, record the higher or highest values		Characteristics of primary supply overcurrent protective device(s)					
System type(s)		Number and type of live conductors		Number of sources	Nominal voltage(s)	Nominal frequency, $f^{(1)}$		BS(EN)		Short-circuit capacity			
TN-S	N/A	1-phase (2-wire)	<input checked="" type="checkbox"/>	1-phase (3-wire)	N/A	400	V	1361		16	kA		
TN-C-S	<input checked="" type="checkbox"/>	3-phase (3-wire)	N/A	3-phase (4-wire)	N/A	$U_o^{(1)}$	230	Type	1	Confirmation of polarity	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
TT	N/A	Other	Please state		Single-phase Prospective fault current, $I_{pf}^{(2/3)}$		16	kA	Rated current	63	A		
					3-phase Prospective fault current, $I_{pf}^{(2/3)}$		N/A	kA					

PARTICULARS OF INSTALLATION AT THE ORIGIN		Tick boxes and enter details, as appropriate						Main switch or circuit-breaker							
Means of earthing		Details of installation earth electrode (where applicable)		Protective measure(s) for fault protection	Measured $Z_e$			Type BS(EN)	BS EN 60947-3 Isolator	Voltage rating	230	V			
Distributor's facility	<input checked="" type="checkbox"/>	Type (eg rod(s), tape etc)	N/A	Location				No of poles	2	Rated current, $I_n$	80	A			
Installation earth electrode	N/A	Electrode resistance, $R_A$	$\Omega$	Method of measurement	ADS	Maximum demand (Load)		Supply conductors material	copper	RCD operating current, $I_{\Delta n}^*$	N/A	mA			
Earthing conductor		Main protective bonding conductors and bonding of extraneous-conductive-parts (✓)		Conductor material	copper	Conductor csa	16	mm <sup>2</sup>	Water service	<input checked="" type="checkbox"/>	Oil service	N/A	Gas service	<input checked="" type="checkbox"/>	
Conductor material	copper	Continuity/connection verified	<input checked="" type="checkbox"/>	Location (where not obvious)		Structural steel	N/A	Other incoming service(s)	N/A	Supply conductors csa	25	mm <sup>2</sup>	RCD operating time (at $I_{\Delta n}^*$ )	N/A	ms
Conductor csa	10	mm <sup>2</sup> connection verified	<input checked="" type="checkbox"/>					* applicable only where an RCD is used as a main circuit-breaker							

SCHEDULE OF ITEMS INSPECTED		† See note below		Additional protection		Cables and conductors (cont)		SCHEDULE OF ITEMS TESTED	
<b>Protective measures against electric shock</b> <b>Basic and fault protection</b> Extra-low voltage <input checked="" type="checkbox"/> SELV Double or reinforced insulation <input checked="" type="checkbox"/> Double or reinforced insulation <b>Basic protection</b> <input checked="" type="checkbox"/> Insulation of live parts <input checked="" type="checkbox"/> Barriers or enclosures <b>Fault protection</b> Automatic disconnection of supply <input checked="" type="checkbox"/> Presence of earthing conductor <input checked="" type="checkbox"/> Presence of circuit protective conductors <input checked="" type="checkbox"/> Presence of main protective bonding conductors <input checked="" type="checkbox"/> Presence of adequate arrangements for other source(s), where applicable <input checked="" type="checkbox"/> Choice and setting of protective devices (for fault protection and/or overcurrent) <b>Electrical separation</b> <input checked="" type="checkbox"/> For one item of current-using equipment		<input checked="" type="checkbox"/> Presence of residual current device(s) <input checked="" type="checkbox"/> Presence of supplementary bonding conductors <b>Prevention of mutual detrimental influence</b> <input checked="" type="checkbox"/> Proximity of non-electrical services and other influences <input checked="" type="checkbox"/> Segregation of Band I and Band II circuits or Band II insulation used <input checked="" type="checkbox"/> Segregation of safety circuits <b>Identification</b> <input checked="" type="checkbox"/> Presence of diagrams, instructions, circuit charts and similar information <input checked="" type="checkbox"/> Presence of danger notices <input checked="" type="checkbox"/> Presence of other warning notices, including presence of mixed wiring colours <input checked="" type="checkbox"/> Labelling of protective devices, switches and terminals <input checked="" type="checkbox"/> Identification of conductors <b>Cables and conductors</b> <input checked="" type="checkbox"/> Selection of conductors for current-carrying capacity and voltage drop <input checked="" type="checkbox"/> Erection methods		<input checked="" type="checkbox"/> Routing of cables in prescribed zones <input checked="" type="checkbox"/> Cables incorporating earthed armour or sheath, or run in an earthed wiring system, or otherwise adequately protected against nails, screws and the like <input checked="" type="checkbox"/> Additional protection by 30 mA RCD (where required, in premises not under the supervision of a skilled or instructed person) <input checked="" type="checkbox"/> Connection of conductors <input checked="" type="checkbox"/> Presence of fire barriers, suitable seals and protection against thermal effects <b>General</b> <input checked="" type="checkbox"/> Presence and correct location of appropriate devices for isolation and switching <input checked="" type="checkbox"/> Adequacy of access to switchgear and other equipment <input checked="" type="checkbox"/> Particular protective measures for special installations and locations <input checked="" type="checkbox"/> Connection of single-pole devices for protection or switching in line conductors only <input checked="" type="checkbox"/> Correct connection of accessories and equipment <input checked="" type="checkbox"/> Selection of equipment and protective measures appropriate to external influences <input checked="" type="checkbox"/> Selection of appropriate functional switching devices		<input checked="" type="checkbox"/> External earth fault loop impedance, $Z_e$ N/A Installation earth electrode resistance, $R_A$ <input checked="" type="checkbox"/> Continuity of protective conductors <input checked="" type="checkbox"/> Continuity of ring final circuit conductors <input checked="" type="checkbox"/> Insulation resistance between live conductors <input checked="" type="checkbox"/> Insulation resistance between live conductors and earth <input checked="" type="checkbox"/> Polarity <input checked="" type="checkbox"/> Earth fault loop impedance, $Z_s$ <input checked="" type="checkbox"/> Verification of phase sequence <input checked="" type="checkbox"/> Operation of residual current device(s) <input checked="" type="checkbox"/> Functional testing of assemblies <input checked="" type="checkbox"/> Verification of voltage drop			
								† See note below	

† All boxes must be completed. '✓' indicates that an inspection or a test was carried out and that the result was satisfactory. 'N/A' indicates that an inspection or test was not applicable to the particular installation.

‡ Where a smoke alarm has been installed, separate certification is required on the appropriate form.

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

## CIRCUIT DETAILS

## TEST RESULTS

Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa		Max. disconnection time (s) by BS 7671	Overcurrent protective devices				RCD Operating current, I <sub>Δn</sub> (mA)	Maximum Z <sub>s</sub> permitted by BS 7671 (Ω)	Circuit impedances (Ω)					Insulation resistance				Polarity (✓)	Maximum measured earth fault loop impedance, Z <sub>s</sub> (Ω)	RCD												
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line	Line/Neutral	Line/Earth	Neutral/Earth			operating times	Test button operation											
														r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )	R <sub>2</sub>	(MΩ)	(MΩ)	(MΩ)	(MΩ)			at I <sub>Δn</sub>	at 5 I <sub>Δn</sub> (if applicable)											
					*																																
<b>1</b>	<b>Distribution Board</b>																																				

Location of consumer unit: Main Incomer-Basement  
 Designation of consumer unit: Isolator Switch  
 Prospective fault current at consumer unit: 0.502 kA

## TEST INSTRUMENTS

Test instruments (serial numbers) used

Multi-function	Insulation resistance	6007773	Continuity	6007773	Earth electrode resistance	Earth fault loop impedance	6006899	RCD	6006899
----------------	-----------------------	---------	------------	---------	----------------------------	----------------------------	---------	-----	---------

**CODES FOR TYPE OF WIRING**

A	Thermoplastic insulated/sheathed cables
B	Thermoplastic cables in non-metallic conduit
C	Thermoplastic cables in non-metallic conduit
D	Thermoplastic cables in metallic trunking
E	Thermoplastic cables in non-metallic trunking
F	Thermoplastic SWA cables
G	Thermosetting SWA cables
H	Mixed metal cables
O	(Other - please state)

**Original** (To the person ordering the work)

CIRCUIT DETAILS												TEST RESULTS																									
Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD	Circuit impedances (Ω)						Insulation resistance				RCD														
					Live (mm²)	cpc (mm²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)		Operating current, I <sub>Δn</sub> (mA)	Maximum Z <sub>s</sub> permitted by BS 7671 (Ω)	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)			Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)	Polarity (✓)	Maximum measured earth fault loop impedance, Z <sub>s</sub> (Ω)	operating times		Test button operation (✓)								
															r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )	R <sub>2</sub>	at I <sub>Δn</sub> (ms)							at 5 I <sub>Δn</sub> (if applicable) (ms)										
*	Distribution Board																																				
1	Hob	A	102	1	6	2.5	0.4	60898	B	40	6	30	1.15	N/A	N/A	N/A	N/A	0.24	N/A	20	20	20	✓	0.77	34	16	✓										
2	Oven	A	102	1	2.5	1.5	0.4	60898	B	16	6	30	2.88	N/A	N/A	N/A	N/A	0.24	N/A	20	20	20	✓	0.54	34	16	✓										
3	Boiler	A	102	1	2.5	1.5	0.4	60898	B	16	6	30	2.88	N/A	N/A	N/A	N/A	0.26	N/A	20	20	20	✓	0.56	34	16	✓										
4	SPARE																																				
5	Sockets General	A	102	15	2.5	1	0.4	60898	B	32		30	1.44	0.39	0.39	0.56	0.2	N/A	N/A	20	20	20	✓	0.97	49	20	✓										
6	Lights general	A	100	19	1	1	0.4	60898	B	6	6	30	7.66	N/A	N/A	N/A	N/A	0.78	N/A	20	20	20	✓	0.89	49	20	✓										
7	Smoke Alarm	A	100	3	1	1	0.4	60898	B	6	6	30	7.66	N/A	N/A	N/A	N/A	0.89	N/A	20	20	20	✓	0.87	49	20	✓										
8	SPARE																																				

Location of consumer unit: **Hallway** Designation of consumer unit: **Distribution Board** Prospective fault current at consumer unit: **.409** kA

TEST INSTRUMENTS		Test instruments (serial numbers) used	
Multi-function	Insulation resistance	6007773	Continuity 6007773
	Earth electrode resistance		Earth fault loop impedance 6006899
	RCD	6006899	

CODES FOR TYPE OF WIRING					
A	B	C	D	E	F
Thermoplastic cables in non-metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in non-metallic conduit
G	H	0 (Other - please state)			
Thermoplastic SWA cables	Mineral-insulated cables				



# ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with *British Standard 7671 – Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable, LU5 5ZX

Original (To the person ordering the work)

DETAILS OF THE CLIENT		
Client / Address:	Mr David Micheal Bath Street, Stroud, Gloucestershire	GL5 3BZ

DETAILS OF THE INSTALLATION		The installation is:	
Address:	Flat 7, Bath Street, Stroud, Gloucestershire	GL5 3BZ	New <input checked="" type="checkbox"/>
Extent of the installation covered by this certificate:	Fixed wiring only, Flat 7		An addition <input type="checkbox"/>
			An alteration <input type="checkbox"/>

DESIGN			
I/We, being the person(s) responsible for the design of the electrical installation (as indicated by my/our signature(s) below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, hereby CERTIFY that the design work for which I/we have been responsible is, to the best of my/our knowledge and belief, in accordance with BS 7671 amended to _____ (date) except for the departures, if any, detailed as follows:			
Details of departures from BS 7671, as amended (Regulations 120.3, 133.5): _____			
The extent of liability of the signatory/signatories is limited to the work described above as the subject of this certificate.			
For the <b>DESIGN</b> of the installation: <span style="float: right;">**(Where there is divided responsibility for the design)</span>			
Signature _____	Date _____	Name (CAPITALS) _____	Designer 1
Signature _____	Date _____	Name (CAPITALS) _____	** Designer 2

CONSTRUCTION			
I/We, being the person(s) responsible for the construction of the electrical installation (as indicated by my/our signature below), particulars of which are described above, having exercised reasonable skill and care when carrying out the construction, hereby CERTIFY that the construction work for which I/we have been responsible is, to the best of my/our knowledge and belief, in accordance with BS 7671 amended to _____ (date) except for the the departures, if any, detailed as follows:			
Details of departures from BS 7671, as amended (Regulations 120.3, 133.5): _____			
The extent of liability of the signatory is limited to the work described above as the subject of this certificate.			
For the <b>CONSTRUCTION</b> of the installation:			
Signature _____	Date _____	Name (CAPITALS) _____	Constructor

INSPECTION AND TESTING			
I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby CERTIFY that the work for which I/we have been responsible is to the best of my/our knowledge and belief in accordance with BS 7671, amended to _____ (date) except for the departures, if any, detailed as follows:			
Details of departures from BS 7671, as amended (Regulations 120.3, 133.5): _____			
The extent of liability of the signatory/signatories is limited to the work described above as the subject of this certificate.			
For the <b>INSPECTION AND TESTING</b> of the installation:			
Signature _____	Date _____	Signature _____	Reviewed by _____
Name (CAPITALS) _____	Inspector	Name (CAPITALS) _____	Qualified Supervisor †

DESIGN, CONSTRUCTION, INSPECTION AND TESTING *			
I, being the person responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671, amended to _____ (date) except for the departures, if any, detailed as follows:			
Details of departures from BS 7671, as amended (Regulations 120.3, 133.5): _____			
The extent of liability of the signatory is limited to the work described above as the subject of this certificate.			
For the <b>DESIGN</b> , the <b>CONSTRUCTION</b> and the <b>INSPECTION AND TESTING</b> of the installation:			
Signature	Date 20/07/2015	Signature _____	Reviewed by _____
Name (CAPITALS) KEVIN KEATES		Name (CAPITALS) _____	Qualified Supervisor ††

† Where the inspection and testing have been carried out by an Approved Contractor, the inspection and testing results are to be reviewed by the registered Qualified Supervisor.  
 †† Where the design, the construction, and the inspection and testing have been the responsibility of one person, the inspection and testing results are to be reviewed by the registered Qualified Supervisor.

Check your certificate is genuine, go to [www.checkmyniceicert.com](http://www.checkmyniceicert.com) and put in the certificate number

## NOTES FOR RECIPIENT

### THIS SAFETY CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE

This safety certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected, tested and verified in accordance with the national standard for the safety of electrical installations, British Standard 7671 (as amended) - *Requirements for Electrical Installations*.

Where, as will often be the case, the installation incorporates a residual current device (RCD), there should be a notice at or near the main switchboard or consumer unit stating that the device should be tested at quarterly intervals. For safety reasons, it is important that you carry out the test regularly.

Also for safety reasons, the complete electrical installation will need to be inspected and tested at appropriate intervals by a competent person. NICEIC\* recommends that you engage the services of an Approved Contractor for this purpose. The maximum interval recommended before the next inspection is stated on Page 2 under *Next Inspection*. There should be a notice at or near the main switchboard or consumer unit indicating when the inspection of the installation is next due.

Only an NICEIC Approved Contractor or Conforming Body responsible for the **construction** of the electrical installation is authorised to issue this NICEIC Electrical Installation Certificate.

The certificate consists of at least five numbered pages. The certificate is invalid if any of the five pages are missing. The certificate has a printed seven-digit serial number which is traceable to the Approved Contractor to which it was supplied by NICEIC.

For installations having more than one distribution board or more circuits than can be recorded on pages 4 and 5, one or more additional *Schedules of Circuit Details for the Installation*, and *Schedules of Test Results for the Installation* (pages 6 and 7 onwards) should form part of the certificate.

This certificate is intended to be issued only for a new electrical installation or for new work associated with an alteration or addition to an existing installation. It should not have been issued for the inspection of an existing electrical installation. An 'Electrical Installation Condition Report' or, where appropriate, a Domestic Electrical Installation Condition Report should be issued for such a periodic inspection.

This certificate should not have been issued for electrical work in a potentially explosive atmosphere (hazardous area) unless the Approved Contractor holds an appropriate extension to NICEIC enrolment for such work.

You should have received the certificate marked 'Original' and the Approved Contractor should have retained the certificate marked 'Duplicate'.

**If you were the person ordering the work, but not the user of the installation, you should pass this certificate, or a full copy of it including these notes, the schedules and additional pages (if any), immediately to the user.**

**The 'Original' certificate should be retained in a safe place and shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new user that the electrical installation complied with the requirements of the national electrical safety standard at the time the certificate was issued.**

Page 1 of this certificate provides details of the electrical installation, together with the name(s) and signature(s) of the person(s) certifying the three elements of installation work: design, construction and inspection and testing. Page 2 identifies the organisation(s) responsible for the work certified by their representative(s).

Certification for inspection and testing provides an assurance that the electrical installation work has been fully inspected and tested, and that the electrical work has been carried out in accordance with the requirements of BS 7671 (except for any departures sanctioned by the designer) and recorded in the appropriate box(es) of the certificate.

\* NICEIC is a part of the Ascertiva Group, a wholly owned subsidiary of The Electrical Safety Council. Under license from The Electrical Safety Council, NICEIC acts as the electrical contracting industry's independent voluntary body for electrical installation safety matters throughout the UK, and maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).

For further information about electrical safety and how NICEIC can help you, visit **[www.niceic.com](http://www.niceic.com)**

continued on the reverse of page 2

## **NOTES FOR RECIPIENT**

### **(continued from the reverse of page 1)**

Where responsibility for the *design*, the *construction* and the *inspection and testing* of the electrical work is divided between the Approved Contractor and one or more other bodies, the division of responsibility should have been established and agreed before commencement of the work. In such a case, NICEIC considers that the absence of certification for the *construction*, or the *inspection and testing* elements of the work would render the certificate invalid. If the *design* section of the certificate has not been completed, NICEIC recommends that you question why those responsible for the design have not certified that this important element of the work is in accordance with the national electrical safety standard.

Where the electrical work to which this certificate relates includes the installation of a fire alarm system and/or an emergency lighting system (or a part of such systems) in accordance with British Standards BS 5839 and BS 5266 respectively, this electrical safety certificate should be accompanied by a separate certificate or certificates as prescribed by those standards.

Where the installation can be supplied by more than one source, such as the public supply and a standby generator, the number of sources should have been recorded in the box entitled Number of Sources, under the general heading *Supply Characteristics and Earthing Arrangements* on page 2 of the certificate, and the *Schedule of Test Results* compiled accordingly. Where a number of sources are available to supply the installation, and where the data given for the primary source may differ from other sources, an additional page should have been provided which gives the relevant information relating to each additional source, and to the associated earthing arrangements and main switchgear.

Should the person ordering the work (e.g. the client, as identified on Page 1 of this certificate), have reason to believe that any element of the work for which the Approved Contractor has accepted responsibility (as indicated by the signatures on this certificate) does not comply with the requirements of the national electrical safety standard (BS 7671), the client should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

**PARTICULARS OF THE ORGANISATION(S) RESPONSIBLE FOR THE ELECTRICAL INSTALLATION**

<b>DESIGN (1)</b>	Organisation †	K M Keates Electrical Contracting L						
Address:	Manor Farm House Gloucester	NICEIC Enrolment No (where appropriate)	0	1	2	2	0	9
	Postcode	GL2 5JU	Branch number: (if applicable)		0	0	0	
<b>DESIGN (2)</b>	Organisation †							
Address:		NICEIC Enrolment No (where appropriate)						
	Postcode		Branch number: (if applicable)					
<b>CONSTRUCTION</b>	Organisation †	K M Keates Electrical Contracting L						
Address:	Manor Farm House Gloucester	NICEIC Enrolment No (Essential information)	0	1	2	2	0	9
	Postcode	GL2 5JU	Branch number: (if applicable)		0	0	0	
<b>INSPECTION AND TESTING</b>	Organisation †	K M Keates Electrical Contracting L						
Address:	Manor Farm House Gloucester	NICEIC Enrolment No (where appropriate)	0	1	2	2	0	9
	Postcode	GL2 5JU	Branch number: (if applicable)		0	0	0	

**SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS**

System Type(s)		Number and Type of Live Conductors				Nature of Supply Parameters			Characteristics of Primary Supply Overcurrent Protective Device(s)			
TN-S	N/A	a.c.	<input checked="" type="checkbox"/>	d.c.	<input type="checkbox"/>	Nominal voltage(s):	400 V	$U_o^{(1)}$	230 V	BS(EN)	1361	
TN-CS		1-phase (2-wire)	N/A	1-phase (3-wire)	<input checked="" type="checkbox"/>	Nominal frequency, $f^{(1)}$	50 Hz	Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one supply, record the higher or highest values			Type	1
TN-C	N/A	2-phase (3-wire)	N/A	3-pole	N/A	Prospective fault current, $I_{pr}^{(2)/(3)}$	16 kA				Rated current	100 A
TT	N/A	3-phase (3-wire)	N/A	3-phase (4-wire)	N/A	External earth fault loop impedance, $Z_e^{(2)/(3)}$	0.35 $\Omega$				Short-circuit capacity	16 kA
IT	N/A	Other	Please state			Number of sources	1				Confirmation of polarity	<input checked="" type="checkbox"/> (✓)

**PARTICULARS OF INSTALLATION AT THE ORIGIN**

Tick boxes and enter details, as appropriate

<b>Means of Earthing</b>		<b>Details of Installation Earth Electrode (where applicable)</b>			
Distributor's facility:	<input checked="" type="checkbox"/>	Type: (eg rod(s), tape etc)	Location:		
Installation earth electrode:	N/A	Electrode resistance, $R_A$ :	( $\Omega$ )	Method of measurement:	
<b>Main Switch or Circuit-Breaker</b>		<b>Maximum Demand (Load):</b>		kVA / Amps	<b>Protective measures against electric shock:</b>
* (applicable only where an RCD is suitable and is used as a main circuit-breaker)				*Delete as appropriate	
Type BS(EN)	BS EN 60947-3 Isolator	Voltage rating	230 V	<b>Earthing and Protective Bonding Conductors</b>	
No of poles	2	Rated current, $I_n$	100 A	<b>Main protective bonding conductors</b>	
Supply conductors material	copper	RCD operating current, $I_{\Delta n}$ *	N/A mA	Conductor material	copper
Supply conductors csa	16 mm <sup>2</sup>	RCD operating time (at $I_{\Delta n}$ )*	N/A ms	Conductor csa	16 mm <sup>2</sup>
				Continuity/connection verified	<input checked="" type="checkbox"/> (✓)
				Continuity/connection verified	<input checked="" type="checkbox"/> (✓)
				<b>Bonding of extraneous-conductive-parts (✓)</b>	
				Water service	<input checked="" type="checkbox"/>
				Gas service	<input checked="" type="checkbox"/>
				Oil service	N/A
				Structural steel	N/A
				Lightning protection	N/A
				Other incoming service(s)	

**COMMENTS ON EXISTING INSTALLATION**

In the case of an alteration or additions see Section 633 None

Note: Enter 'NONE' or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation.

**NEXT INSPECTION**

§ Enter interval in terms of years, months or weeks, as appropriate

§ 10 Years

I/We, the designer(s), RECOMMEND that this installation is further inspected and tested after an interval of not more than

Tick boxes and enter details, as appropriate

† Where the Approved Contractor responsible for the construction of the electrical installation has also been responsible for the design and the inspection and testing of that installation, the 'Particulars of the Organisation responsible for the Electrical Installation' may be recorded only in the section entitled 'CONSTRUCTION'.

‡ Where a number of sources are available to supply the installation, and where the data given for the primary source may differ from other sources, a separate sheet must be provided which identifies the relevant information relating to each additional source.

**SCHEDULE OF ITEMS INSPECTED**

† See note below

**PROTECTIVE MEASURES AGAINST ELECTRIC SHOCK**

**Basic and fault protection**

**Extra-low voltage**

✓ SELV N/A PELV

**Double or reinforced insulation**

✓ Double or Reinforced Insulation

**Basic protection**

✓ Insulation of live parts ✓ Barriers or enclosures  
 ✓ Obstacles \*\* ✓ Placing out of reach \*\*

**Fault protection**

**Automatic disconnection of supply**

✓ Presence of earthing conductor  
 ✓ Presence of circuit protective conductors  
 ✓ Presence of main protective bonding conductors  
 ✓ Presence of earthing arrangements for combined protective and functional purposes  
 ✓ Presence of adequate arrangements for other source(s), where applicable  
 N/A FELV  
 ✓ Choice and setting of protective and monitoring devices (for fault protection and/or overcurrent protection)

**Non-conducting location \*\***

✓ Absence of protective conductors

**Earth-free equipotential bonding \*\***

N/A Presence of earth-free equipotential bonding

**Electrical separation**

✓ For **one** item of current-using equipment  
 ✓ For **more** than one item of current-using equipment \*\*

**Additional protection**

✓ Presence of residual current device(s)  
 ✓ Presence of supplementary bonding conductors

\*\* For use in controlled supervised/conditions only

**Prevention of mutual detrimental influence**

✓ Proximity of non-electrical services and other influences  
 ✓ Segregation of Band I and Band II circuits or Band II insulation used  
 ✓ Segregation of Safety Circuits

**Identification**

✓ Presence of diagrams, instructions, circuit charts and similar information  
 ✓ Presence of danger notices and other warning notices  
 ✓ Labelling of protective devices, switches and terminals  
 ✓ Identification of conductors

**Cables and Conductors**

✓ Selection of conductors for current-carrying capacity and voltage drop  
 ✓ Erection methods  
 ✓ Routing of cables in prescribed zones  
 ✓ Cables incorporating earthed armour or sheath, or run in an earthed wiring system, or otherwise adequately protected against nails, screws and the like  
 ✓ Additional protection by 30 mA RCD for cables concealed in walls (where required, in premises not under the supervision of a skilled or instructed person)  
 ✓ Connection of conductors  
 ✓ Presence of fire barriers, suitable seals and protection against thermal effects

**General**

✓ Presence and correct location of appropriate devices for isolation and switching  
 ✓ Adequacy of access to switchgear and other equipment  
 ✓ Particular protective measures for special installations and locations  
 ✓ Connection of single-pole devices for protection or switching in line conductors only  
 ✓ Correct connection of accessories and equipment  
 ✓ Presence of undervoltage protective devices  
 ✓ Selection of equipment and protective measures appropriate to external influences  
 ✓ Selection of appropriate functional switching devices

**SCHEDULE OF ITEMS TESTED**

† See note below

✓ External earth fault loop impedance,  $Z_e$   
 N/A Installation earth electrode resistance,  $R_A$   
 ✓ Continuity of protective conductors  
 ✓ Continuity of ring final circuit conductors  
 ✓ Insulation resistance between live conductors  
 ✓ Insulation resistance between live conductors and Earth  
 ✓ Protection by separation of circuits

✓ Basic protection by barrier or enclosure provided during erection  
 ✓ Insulation of non-conducting floors or walls  
 ✓ Polarity  
 ✓ Earth fault loop impedance,  $Z_s$   
 ✓ Verification of phase sequence  
 ✓ Operation of residual current devices  
 ✓ Functional testing of assemblies  
 ✓ Verification of voltage drop

**SCHEDULE OF ADDITIONAL RECORDS\* (See attached schedule)**

Page No(s)

Note: Additional page(s) must be identified by the Electrical Installation Certificate serial number and page number(s).

† All boxes must be completed. '✓' indicates that an inspection or a test was carried out and that the result was **satisfactory**. 'N/A' indicates that an inspection or test was **not applicable** to the particular installation.

\* Where the electrical work to which this certificate relates includes the installation of a fire alarm system and/or an emergency lighting system (or a part of such systems), this electrical safety certificate should be accompanied by the particular certificate(s) for the system(s).










## SCHEDULE OF TEST RESULTS FOR THE INSTALLATION - CONTINUATION

<p><b>TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION</b></p> <p style="text-align: center;">Characteristics at this distribution board</p> <p style="text-align: center;"> <input checked="" type="checkbox"/> Confirmation of supply polarity         </p> <p> <small>* See note below</small>  <math>Z_s^*</math> <b>0.44</b> <math>\Omega</math>    Operating times of associated RCD (if any)    At <math>I_{\Delta n}</math> <b>N/A</b> ms  <math>I_{pf}^*</math> <b>0.836</b> kA    At <math>5I_{\Delta n}</math> (if applicable) <b>N/A</b> ms         </p>	<p style="text-align: center;"><b>Test instruments (serial numbers) used:</b></p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Earth fault loop impedance</td> <td style="width: 40%;">6006899</td> <td style="width: 10%;">RCD</td> <td style="width: 20%;">6006899</td> </tr> <tr> <td>Insulation resistance</td> <td>6007773</td> <td>Multi-function</td> <td></td> </tr> <tr> <td>Continuity</td> <td>6007773</td> <td>Other</td> <td></td> </tr> </table>	Earth fault loop impedance	6006899	RCD	6006899	Insulation resistance	6007773	Multi-function		Continuity	6007773	Other	
Earth fault loop impedance	6006899	RCD	6006899										
Insulation resistance	6007773	Multi-function											
Continuity	6007773	Other											

### TEST RESULTS

Circuit number and line	Circuit impedances ( $\Omega$ )					Insulation resistance <i>Record lower or lowest value</i>				Polarity ( $\checkmark$ )	Maximum measured earth fault loop impedance, $Z_s^*$ ( $\Omega$ )	RCD		
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line (M $\Omega$ )	Line/Neutral (M $\Omega$ )	Line/Earth (M $\Omega$ )	Neutral/Earth (M $\Omega$ )			Operating times		Test button operation ( $\checkmark$ )
	$r_1$ (Line)	$r_n$ (Neutral)	$r_2$ (cpc)	( $R_1 + R_2$ )	$R_2$							at $I_{\Delta n}$ (ms)	at $5I_{\Delta n}$ (if applicable) (ms)	
1	0.4	0.4	0.61	0.29	N/A	N/A	20	20	20	$\checkmark$	0.69	52	12	$\checkmark$
2	N/A	N/A	N/A	0.12	N/A	N/A	20	20	20	$\checkmark$	0.52	52	12	$\checkmark$
3	N/A	N/A	N/A	0.58	N/A	N/A	20	20	20	$\checkmark$	0.67	52	12	$\checkmark$
4														
5	N/A	N/A	N/A	0.25	N/A	N/A	20	20	20	$\checkmark$	0.78	52	12	$\checkmark$
6	N/A	N/A	N/A	0.89	N/A	N/A	20	20	20	$\checkmark$	0.55	52	12	$\checkmark$
7	N/A	N/A	N/A	0.76	N/A	N/A	20	20	20	$\checkmark$	0.67	52	12	$\checkmark$
8														

\* Note: Where the installation can be supplied by more than one source, such as a primary source (e.g. public supply) and a secondary source (e.g. standby generator), the higher or highest values must be recorded.

Signature: 	Position: MD
Name: <b>KEVIN KEATES</b> <small>(CAPITALS)</small>	Date of testing: 20/07/2015

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with *British Standard 7671 – Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZK

CRN/ Contractor's Reference Number

## DETAILS OF THE CLIENT

Client and address  
 Mr David Micheal  
 Bath Street  
 Stroud  
 Gloucestershire  
 Postcode GL5 3BZ

## ADDRESS OF THE INSTALLATION

Installation address  
 Bath Street  
 Stroud  
 Gloucestershire  
 Postcode GL5 3BZ

## DETAILS OF THE INSTALLATION

Extent of the installation work covered by this certificate  
 Fixed wiring only, Basement & Landlords area's

The installation is  
 New   
 An addition   
 An alteration

## DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I, being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my signature adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671, 17th Edition amended to 2015 (date) except for the departures, if any, detailed as follows:  
 Details of departures from BS 7671, as amended (Regulations 120.3, 133.5)

The extent of liability of the signatory is limited to the work described above as the subject of this certificate. For the **DESIGN**, the **CONSTRUCTION** and the **INSPECTION AND TESTING** of the installation

Signature  Name (CAPITALS) KEVIN KEATES Date 20/08/2015

### The results of the inspection and testing reviewed by the Qualified Supervisor

Signature  Name (CAPITALS) KEVIN KEATES Date 20/08/2015

## PARTICULARS OF THE APPROVED CONTRACTOR

Trading title  
 K M Keates Electrical Contracting L

Address  
 Manor Farm House  
 Gloucester

Telephone No 07831 695 185 Postcode GL2 5JU

NICEIC Enrolment No (Essential information) 0 1 2 2 0 9 Branch No (if applicable) 0 0 0

## NEXT INSPECTION

§ Enter interval in terms of years, months or weeks, as appropriate

I RECOMMEND that this installation is further inspected and tested after an interval of not more than 5 years

## COMMENTS ON EXISTING INSTALLATION

Note: Enter 'NONE' or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation

None

In the case of an alteration or additions see Section 633 of BS 7671

## SCHEDULE OF ADDITIONAL RECORDS\*

See attached schedule

\* Where the electrical work to which this certificate relates includes the installation of a fire detection/ alarm system (or a part of such a system), this electrical safety certificate should be accompanied by the particular certificate for the system.

This certificate is based on the model forms shown in Appendix 6 of BS 7671.

Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

## NOTES FOR RECIPIENT

**THIS SAFETY CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE**

**IF YOU WERE THE PERSON ORDERING THE WORK, BUT NOT THE OWNER OR USER OF THE INSTALLATION, YOU SHOULD PASS THIS CERTIFICATE, OR A FULL COPY OF IT INCLUDING THESE NOTES, IMMEDIATELY TO THE OWNER OR USER OF THE INSTALLATION.**

**This safety certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected, tested and verified in accordance with the national standard for the safety of electrical installations, British Standard 7671 (as amended) - *Requirements for Electrical Installations* (the IET Wiring Regulations).**

**Where, as will often be the case, the installation incorporates a residual current device (RCD), there should be a notice at or near the consumer unit stating that the device should be tested at quarterly intervals. For safety reasons, it is important that you carry out the test regularly.**

**Also for safety reasons, the complete electrical installation will need to be inspected and tested at appropriate intervals by a skilled person or persons competent in such work. NICEIC\* recommends that you engage the services of an Approved Contractor for this purpose. The maximum interval recommended before the next inspection is stated on Page 1 under *Next Inspection*. There should also be a notice at or near the consumer unit indicating when the inspection of the installation is next due.**

Only an NICEIC Approved Contractor or Conforming Body responsible for the construction of the electrical installation is authorised to issue this NICEIC certificate.

The Domestic Electrical Installation Certificate consists of at least four pages. The certificate is invalid if pages (containing schedules) are missing. The certificate has a printed seven-digit serial number which is traceable to the Approved Contractor to which it was supplied.

This certificate is intended to be issued for either the initial certification of a new electrical installation, or for new work associated with an alteration or addition to an existing electrical installation, in a single dwelling (house or individual flat). For new electrical installation work in other than a single dwelling, a full Electrical Installation Certificate should have been issued.

This certificate should not have been issued for reporting on the condition of an existing electrical installation. An Electrical Installation Condition Report or, where appropriate, a Domestic Electrical Installation Condition Report should be issued for such an inspection.

You should have received the certificate marked 'Original' and the Approved Contractor should have retained the certificate marked 'Duplicate'.

**The 'Original' certificate should be kept in a safe place and shown to any person inspecting or undertaking work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new owner or user that the electrical installation work complied with the requirements of the national electrical safety standard at the time the certificate was issued.**

Page 1 of this certificate provides details of the electrical installation, together with the names and signatures of the persons certifying the installation work and reviewing the results of inspection and testing on behalf of the Approved Contractor responsible for the work, details of which are also given on that page.

Certification provides an assurance that the electrical installation work has been fully inspected and tested, and that the work has been carried out in accordance with the requirements of BS 7671 (except for any departures recorded in the appropriate part of the certificate).

All unshaded boxes should have been completed either by insertion of the relevant details or by entering 'N/A', meaning 'Not Applicable', where appropriate.

Where the electrical work to which this certificate relates includes the provision of a mains powered fire detection and alarm system (such as one or more smoke alarms), this electrical safety certificate must be accompanied by a separate certificate for that system in accordance with British Standard BS 5839-6: 2013: *Fire detection and fire alarm systems for buildings - Part 6: Code of practice for the design, installation, commissioning and maintenance of fire detection and fire alarm systems in domestic premises*.

Should the person ordering the work (e.g. the client, as identified on Page 1 of this certificate) have reason to believe that any element of the electrical work for which the Approved Contractor has accepted responsibility (as indicated by the signatures on this certificate) does not comply with the requirements of the national electrical safety standard (BS 7671), the person should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application and from the website. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

*\* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, the Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).*

For further information about electrical safety and how NICEIC can help you,  
**visit [www.niceic.com](http://www.niceic.com)**

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Original (To the person ordering the work)

SUPPLY CHARACTERISTICS		Tick boxes and enter details, as appropriate				Nature of supply parameters				Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one supply, record the higher or highest values				Characteristics of primary supply overcurrent protective device(s)			
System type(s)		Number and type of live conductors		Number of sources		Nominal voltage(s)		Nominal frequency, $f^{(1)}$		External earth fault loop impedance, $Z_e^{(1)}$		BS(EN)		Short-circuit capacity			
TN-S	N/A	1-phase (2-wire)	<input checked="" type="checkbox"/>	1-phase (3-wire)	N/A	400	V	50	Hz	0.35	$\Omega$	BS 88 Fuse HRC gG (General)	16	kA			
TN-C-S	<input checked="" type="checkbox"/>	3-phase (3-wire)	N/A	3-phase (4-wire)	N/A	230	V					Type	gG	Confirmation of supply polarity			
TT	N/A	Other <small>Please state</small>		Single-phase Prospective fault current, $I_{pf}^{(2/3)}$		16	kA	3-phase Prospective fault current, $I_{pf}^{(2/3)}$		N/A		Rated current	100	A			

PARTICULARS OF INSTALLATION AT THE ORIGIN				Tick boxes and enter details, as appropriate				Measured $Z_e$				Main Switch/Switch-Fuse/Circuit-Breaker/RCD			
Means of earthing		Details of installation earth electrode (where applicable)		Protective measure(s) for fault protection		Maximum demand (Load)		Number of smoke alarms		Type BS(EN)		Voltage rating			
Distributor's facility	<input checked="" type="checkbox"/>	Type (eg rod(s), tape etc)	N/A	Location	N/A	ADS	80	Amps	4	BS EN 60947-3 Isolator	230	V			
Installation earth electrode	N/A	Electrode resistance, $R_A$	N/A	Method of measurement	N/A	Delete as appropriate				No of poles	2	Rated current, $I_n$	100	A	
Earthing conductor		Main protective bonding conductors and bonding of extraneous-conductive-parts (✓)		Water installation pipes		Structural steel				Supply conductors material		RCD operating current, $I_{\Delta n}^*$			
Conductor material	copper	Continuity/connection verified	<input checked="" type="checkbox"/>	Conductor material	copper	Conductor csa	10	mm <sup>2</sup>	N/A	copper	N/A	mA			
Conductor csa	16	mm <sup>2</sup>	<input checked="" type="checkbox"/>	Location (where not obvious)		Oil installation pipes	N/A	Other		Supply conductors csa	16	mm <sup>2</sup>	RCD operating time (at $I_{\Delta n}^*$ )	N/A	ms
						Gas installation pipes	<input checked="" type="checkbox"/>					Rated time delay*		N/A	ms

\* applicable only where an RCD is used as a main circuit-breaker

SCHEDULE OF ITEMS INSPECTED		† See note below	
<b>1.0 CONDITION/ADEQUACY OF DISTRIBUTOR'S/SUPPLY INTAKE EQUIPMENT (the Distributor should be notified of any unsatisfactory equipment)</b>			
1.1	Service cable	<input checked="" type="checkbox"/>	
1.2	Service head	<input checked="" type="checkbox"/>	
1.3	Distributor's earthing arrangement	<input checked="" type="checkbox"/>	
1.4	Meter tails - Distributor/Consumer	<input checked="" type="checkbox"/>	
1.5	Metering equipment	<input checked="" type="checkbox"/>	
1.6	Means of main isolation (where present)	<input checked="" type="checkbox"/>	
<b>2.0 PARALLEL OR SWITCHED ALTERNATIVE SOURCES OF SUPPLY</b>			
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	<input checked="" type="checkbox"/>	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	<input checked="" type="checkbox"/>	
2.3	Presence of alternative/additional supply warning notice(s)	<input checked="" type="checkbox"/>	
<b>3.0 AUTOMATIC DISCONNECTION OF SUPPLY</b>			
3.1	Presence and adequacy of protective earthing/ bonding arrangements as follows:		
a)	Distributor's earthing arrangement or installation earth electrode arrangement	<input checked="" type="checkbox"/>	
b)	Earthing conductor and connections	<input checked="" type="checkbox"/>	
c)	Main protective bonding conductors and connections	<input checked="" type="checkbox"/>	
d)	Earthing/bonding labels at all appropriate locations	<input checked="" type="checkbox"/>	
3.2	Accessibility of:		
a)	Earthing conductor connections	<input checked="" type="checkbox"/>	
b)	All protective bonding connections	<input checked="" type="checkbox"/>	
<b>4.0 BASIC PROTECTION</b>			
4.1	Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:		
a)	Insulation of live parts e.g. conductors completely covered with durable insulating materials	<input checked="" type="checkbox"/>	
b)	Barriers or enclosures e.g. correct IP rating	<input checked="" type="checkbox"/>	
<b>5.0 ADDITIONAL PROTECTION</b>			
5.1	Presence and effectiveness of additional protection methods		
a)	RCD(s) not exceeding 30 mA operating current	<input checked="" type="checkbox"/>	
b)	Supplementary bonding	<input checked="" type="checkbox"/>	
<b>6.0 OTHER METHODS OF PROTECTION</b>			
6.1	Basic and fault protection		LOCATION
a)	SELV	<input checked="" type="checkbox"/>	
b)	PELV	<input checked="" type="checkbox"/>	
c)	Double insulation/Reinforced insulation	<input checked="" type="checkbox"/>	
d)	Electrical separation for one item of equipment	<input checked="" type="checkbox"/>	

† All boxes must be completed. ✓ indicates that an inspection was carried out and that the result was satisfactory. 'N/A' indicates that an inspection was not applicable to the particular installation.

‡ Where a smoke alarm has been installed, separate certification is required on the appropriate form.

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Original (To the person ordering the work)

SCHEDULE OF ITEMS INSPECTED <sup>† See note below</sup>	
<b>7.0 CONSUMER UNIT(S)</b>	
7.1 Adequacy of working space/accessibility	✓
7.2 Security of fixing	✓
7.3 Adequacy / security of barriers	✓
7.4 Insulation of live parts not damaged during erection	✓
7.5 Enclosures not damaged during installation	✓
7.6 Suitability of enclosures for IP and fire ratings	✓
7.7 Presence and operation of main switch(es), linked, where appropriate	✓
7.8 Operation of circuit-breakers and RCDs to prove functionality	✓
7.9 Correct identification of circuit protective devices	✓
7.10 RCD(s) provided for fault protection, where specified	✓
7.11 RCD(s) provided for additional protection, where specified	✓
7.12 Confirmation overvoltage protection (SPDs) provided and functional where specified	✓
7.13 Presence of RCD quarterly test notice at or near the origin	✓
7.14 Presence of diagrams, charts or schedules at or near each Consumer unit(s)	✓
7.15 Presence of non-standard (mixed) cable colour warning notice at or near the appropriate distribution board, where required	✓
7.16 Presence of next inspection recommendation label	✓
7.17 Presence of other required labelling	✓
7.18 Selection of protective device(s) and base(s); correct type and rating	✓
7.19 Single-pole protective devices in line conductor only	✓
7.20 Protection against mechanical damage where cables enter equipment	✓
7.21 Protection against electromagnetic effects where cables enter ferromagnetic enclosures	✓
7.22 Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓
<b>8.0 CIRCUITS</b>	
8.1 Identification of conductors	✓
8.2 Cables adequately supported throughout their length	✓
8.3 Examination of cables for signs of mechanical damage during installation	✓
8.4 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓
8.5 Adequacy of protective devices: type and rated current for fault protection	✓
8.6 Presence and adequacy of circuit protective conductors	✓
8.7 Coordination between conductors and overload protective devices	✓
8.8 Non-sheathed cables enclosed throughout (e.g. in conduit/trunking)	✓
8.9 Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage	✓
a) Installed in prescribed zones	✓
b) Incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like	✓
8.10 Provision of additional protection by RCDs having rated residual operating current ( $I_{\Delta n}$ ) not exceeding 30 mA	
a) For mobile equipment with a current rating not exceeding 32 A for use outdoors	✓
b) For all socket-outlets of rating 20 A or less, unless exempt	✓
c) For cables installed in walls/partitions at a depth of less than 50 mm	✓
d) For cables installed in walls/partitions containing metal parts regardless of depth	✓
8.11 Provision of fire barriers, sealing arrangements so as to minimize the spread of fire	✓
8.12 Band II cables segregated/separated from Band I cables	✓
8.13 Cables segregated/separated from non-electrical services	✓
8.14 Termination of cables at enclosures	
a) Connections under no undue strain	✓
b) No basic insulation of a conductor visible outside enclosure	✓
8.15 Circuit accessories not damaged during erection	✓
8.16 Single-pole devices for switching or protection in the line conductors only	✓
8.17 Adequacy of connections, including cpcs, within accessories and at fixed and stationary equipment	✓
8.18 Presence of appropriate devices for isolation and switching correctly located	
a) Accessible means of switching off for mechanical maintenance	✓
b) Correct operation verified (functional check)	✓
<b>9.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)</b>	
9.1 Adequacy of working space/accessibility	✓
9.2 Suitability of equipment in terms of IP and fire ratings	✓
9.3 Enclosure not damaged/deteriorated during installation so as to impair safety	✓
9.4 Cable entry holes in ceilings above luminaires, sized or sealed so as to restrict the spread of fire	✓
9.5 Recessed luminaires (downlighters)	
a) Correct type of lamps fitted	✓
b) Installed to minimise build-up of heat	✓
<b>10.0 LOCATION(S) CONTAINING A BATH OR SHOWER</b>	
10.1 Additional protection by RCD not exceeding 30 mA	
a) For low voltage circuits serving the location	✓
b) For low voltage circuits passing through Zone 1 and Zone 2 not serving the location	✓
10.2 Where used as a protective measure, requirements for SELV or PELV are met	✓
10.3 Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	✓
10.4 Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓
10.5 Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	✓
10.6 Suitability of equipment for external influences for installed location in terms of IP rating	✓
10.7 Suitability of electrical equipment for installation in a particular zone	✓
<b>11.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS</b>	
11.1 List all other special installations or locations present, if any. (Record separately the results of particular inspections applied separately)	

**SCHEDULE OF ITEMS INSPECTED BY:**

Signature:  Name (Capitals): KEVIN KEATES Date: 20/08/2015



# SCHEDULES - CONTINUATION

CIRCUIT DETAILS													TEST RESULTS															
Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices					RCD	Maximum $Z_s$ permitted by BS 7671	Circuit impedances ( $\Omega$ )					Insulation resistance				Polarity	Maximum measured earth fault loop impedance, $Z_g$ ( $\Omega$ )	RCD		
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, $I_{nB}$ (mA)			Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line (M $\Omega$ )	Line/Neutral (M $\Omega$ )	Line/Earth (M $\Omega$ )	Neutral/Earth (M $\Omega$ )			at $I_{\Delta n}$ (ms)	at 5 $I_{\Delta n}$ (if applicable) (ms)	Test button operation ( $\checkmark$ )
															$r_1$ (Line)	$r_n$ (Neutral)	$r_2$ (cpc)	$(R_1 + R_2)$	$R_2$									
					$r_1$ (Line)	$r_n$ (Neutral)	$r_2$ (cpc)	$(R_1 + R_2)$	$R_2$	(M $\Omega$ )	(M $\Omega$ )	(M $\Omega$ )			(M $\Omega$ )	( $\checkmark$ )	(ms)	(ms)	( $\checkmark$ )									
*	Landlords Distributon Board	A	100	1	16	16	5	1361	2	80	16	N/A	0.47	N/A	N/A	N/A	N/A	0.23	N/A	20	20	20	$\checkmark$	0.29	N/A	N/A	$\checkmark$	
1	Fire Alarm	O	C	1	1.5	1.5	5	60898	B	6	6	N/A	7.28	N/A	N/A	N/A	N/A	0.23	N/A	20	20	20	$\checkmark$	0.32	25	19	$\checkmark$	
2	Cooker	A	100	1	6	2.5	5	60898	B	32	6	30	1.36	N/A	N/A	N/A	N/A	0.21	N/A	20	20	20	$\checkmark$	0.85	25	19	$\checkmark$	
3	Sockets Kitchen	A	101	13	2.5	1.5	0.4	60898	B	32	6	30	1.36	0.4	0.4	0.62	0.32	N/A	N/A	20	20	20	$\checkmark$	0.95	25	19	$\checkmark$	
4	Sockets utility	A	101	3	2.5	1.5	0.4	60898	B	32	6	30	1.36	0.32	0.32	0.48	0.21	N/A	N/A	20	20	20	$\checkmark$	1.13	25	19	$\checkmark$	
5	Sockets-workshop-gym	A	100	7	2.5	1.5	0.4	60898	B	32	6	30	1.36	0.67	0.67	0.98	0.41	N/A	N/A	20	20	20	$\checkmark$	1.27	25	19	$\checkmark$	
6	Lights general	A	100	27	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	N/A	0.78	N/A	20	20	20	$\checkmark$	1.22	25	19	$\checkmark$	
7	Sauna	A	101	1	6	2.5	0.4	60898	B	40	6	30	1.09	N/A	N/A	N/A	N/A	0.68	N/A	20	20	20	$\checkmark$	0.98	25	19	$\checkmark$	
8	Sockets General	A	100	7	2.5	1.5	0.4	60898	B	32	6	30	1.36	0.62	0.62	0.86	0.44	N/A	N/A	20	20	20	$\checkmark$	0.85	25	19	$\checkmark$	
9	Sockets Upstairs	A	101	2	2.5	1.5	0.4	60898	B	16	6	30	2.73	N/A	N/A	N/A	N/A	0.65	N/A	20	20	20	$\checkmark$	0.86	23	18	$\checkmark$	
10	Lighting landlords	A	101	14	1	1	5	60898	B	6	6	30	7.28	N/A	N/A	N/A	N/A	0.98	N/A	20	20	20	$\checkmark$	1.23	23	18	$\checkmark$	
11	Lights general	A	101	4	1	1	5	60898	B	6	6	30	7.28	N/A	N/A	N/A	N/A	1.25	N/A	20	20	20	$\checkmark$	1.36	23	18	$\checkmark$	
12	SPARE																											

Location of consumer unit Under Stairs

Designation of consumer unit Landlords Distributon Board

Prospective fault current at consumer unit 0.619 kA

## TEST INSTRUMENTS

Test instruments (serial numbers) used

Multi-function Insulation resistance 6007773 Continuity 6007773 Earth electrode resistance Earth fault loop impedance 6006899 RCD 6006899

**CODES FOR TYPE OF WIRING**  
**A** Thermoplastic cables in sheathed cables  
**B** Thermoplastic cables in metallic conduit  
**C** Thermoplastic cables in non-metallic conduit  
**D** Thermoplastic cables in metallic trunking  
**E** Thermoplastic cables in non-metallic trunking  
**F** Thermoplastic/SWA cables  
**G** Thermoplastic/SWA cables  
**H** Mineral-insulated cables  
**0** (Other - please state)

Original (To the person ordering the work)